

**STATEMENT OF WORK**  
Water Well (642)  
**Iowa**

**These deliverables are the minimum requirements that apply to this individual practice. Refer to practice specific Statements of Work for conservation practices associated with this practice.**

## **PRE-DESIGN**

---

### **Deliverables:**

1. Documents that demonstrate that adequate planning activities have been completed.
  - a. Report or conservation assistance notes summarizing pre-design meeting(s) with client.
    - i. Identify the resource concern being addressed and the landowner objectives.
    - ii. Define roles and responsibilities of all parties that will be involved in the project.
      1. Landowner
      2. Designer
      3. NRCS and/or other funding source(s)
      4. Contractor
    - iii. Advise client on potential compliance issues with federal, state, tribal, and local laws, regulations and NRCS policies.
  - b. The practice is included in a conservation plan and meets one or more of the purpose(s) described in the Conservation Practice Standard.
  - c. Completed IA-CPA-52 showing NEPA requirements have been met and documented (i.e. cultural resources and threatened and endangered (T&E) species).

## **DESIGN**

---

### **Deliverables:**

1. A copy of survey notes which show that a thorough and detailed site survey was completed.
  - a. Survey notes shall be in accordance with NRCS Technical Release 62, Engineering Field Handbook (EFH), Chapter 1, Engineering Surveys, and/or standard industry practice.
  - b. If survey equipment with automatic / electronic data collection devices is used, an electronic copy of the survey shall be provided on a non-volatile medium such as CD-ROM. In lieu of an electronic copy of the data, a print out of the data may be included in the file. Both printed and electronic data shall be provided in a delimited ASCII format that includes point number, easting, northing, elevation, and description for each surveyed point.
  - c. Rod Readings or Elevations shall be referenced to a bench mark. A temporary bench mark (TBM) may be acceptable. The TBM shall be selected to ensure its availability through completion of construction activities.
  - d. LiDAR elevations can only be used for planning purposes.
  - e. The design survey shall meet the accuracy standard for Rough Surveys as presented in EFH Chapter 1. Survey elements required include:
    - i. Topographic survey of land adjacent to the proposed well site showing nearby buildings, other wells, stream channels, and other features.
    - ii. Location of potential sources of pollution.
2. Design documents that demonstrate the criteria in the practice standard have been met and are compatible with other planned and applied practices.
  - a. Practice standard substantiating data, computations, and analyses to develop plans and specifications including but not limited to:
    - i. Geology and soil mechanics (NEM Part 531 – Geology, Subpart 531A).
    - ii. Environmental considerations.
    - iii. Erosion control/Seeding.
    - iv. Safety considerations.
  - b. All design documentation is shown as checked.
  - c. Documentation that adequate land rights have been obtained if needed.

**STATEMENT OF WORK**  
Water Well (642)  
**Iowa**

3. Written plans and specifications which adequately describe the requirements to install the practice and obtain necessary permits (NEM Part 511, Subpart A, Construction Plans, 511.08, and Iowa Amendments; NEM Part 541, Drafting and Drawing; NEM Part 542, Specifications; NEM Part 543, Materials).
  - a. Drawings, which include but are not limited to the following elements:
    - i. Location map and plan view of the site, including the township, range, section, scale, and north arrow.
    - ii. The bench mark elevation and description.
    - iii. A topographic map of the area near the well site.
    - iv. Location of potential sources of pollution.
    - v. Other items required in the current Conservation Practice Standard.
    - vi. A note on the drawings stating that the contractor is responsible for calling Iowa One Call at 1-800-292-8989 at least 48 hours prior to beginning any excavation work.
    - vii. A note on the drawings stating that if a cultural resource is identified during construction, work will stop immediately and the NRCS Archeologist will be notified.
    - viii. The Iowa Engineering Job Class is shown on the drawings (NEM Part 501, Form IA-ENG-6).
    - ix. Completed title block showing dates and the names of the designer and checker, and the signature of the person approving the design.
    - x. Acceptance signature by client.
  - b. Construction and material specifications, including but not limited to:
    - i. A requirement that all well drilling and pump installation shall be performed by an Iowa Department of Natural Resources (IDNR) certified well contractor. The IDNR certified well contractor must be on the job site at the time well services are being performed.
    - ii. Other specifications required for the project.
    - iii. IA-5 Pollution Control Construction Specification or its equivalent is required for all jobs.
4. Design Report (NEM Part 511, Subpart B Design Documentation, 511.11) with detail appropriate to the complexity of the job. If multiple practices are part of a single job, a combined design report may be acceptable. The design report shall include, but not be limited to the following:
  - a. Summary of project objectives.
  - b. Site assessment including the availability of groundwater.
  - c. Summary of design documentation from item 2 listed above.
  - d. List of facilitating practices.
  - e. List of required permits to be obtained by the client.
  - f. Bill of Materials and Itemized Cost Estimate.
  - g. Bid Sheet to be used by the client, if appropriate.
5. Inspection Plan (NEM Part 512, Subpart D Quality Assurance Activities, 512.30 through 512.33) appropriate to the complexity of the job, which describes the following:
  - a. Items of work and materials requiring inspection.
  - b. Type and frequency of testing, if needed.
  - c. The as-built documentation required.
  - d. Quality Control responsibilities.
  - e. Quality Assurance responsibilities.
6. Operation and maintenance plan meeting the requirements of the current Conservation Practice Standard.
7. Certification that the design meets practice standard criteria and complies with applicable laws and regulations (NEM Part 505, Subpart A, 505.03), or is approved by an employee with the appropriate delegated engineering job approval authority (NEM Part 501, Subpart A).

**STATEMENT OF WORK**  
Water Well (642)  
**Iowa**

---

**INSTALLATION**

---

**Deliverables**

1. Pre-installation conference with client and contractor.
  - a. Review plans and specifications
  - b. Review NRCS utility safety policy. (NEM Part 503 – Safety, Subpart A – Engineering Activities Affecting Utilities, Section 503.00 through 503.22 and Iowa amendments).
  - c. Review roles and responsibilities of all parties involved in the project installation.
  - d. The landowner shall provide NRCS a copy of the following items prior to the installation of the well:
    - A signed and completed copy of the IDNR “Application for Non-Public Water Well Construction Permit”
    - A copy of the county “approval” letter for well installation .
2. Staking and layout according to plans and specifications including applicable layout notes.
3. Installation inspection documented in the case file assistance notes or in a job diary to include:
  - a. Dates and record of inspections made, testing completed, instruction provided to the contractor, etc., to document compliance with standards and specifications.
  - b. Actual materials used.
4. Facilitate and implement required design modifications with client, original designer, and permitting and funding agencies. Design modifications required during installation are properly approved and documented.

---

**CHECK OUT**

---

**Deliverables**

1. Survey for Checkout conducted and recorded as for the design survey.
  - a. Well Location
2. As-built documentation (450-GM, IA407).
  - a. Extent of practice units applied.
  - b. Drawings with changes from the original construction plans clearly shown.
  - c. Completed Iowa DNR Well Record Form.
  - d. Water analysis reports before and after disinfection.
3. Certification that the practice has been installed in accordance with NRCS practice standard criteria and specifications and complies with applicable laws and regulations, or is approved by an employee with the appropriate delegated engineering job approval authority (see Design Deliverable Item 7).
4. Progress reporting.

---

**REFERENCES**

---

- Field Office Technical Guide (eFOTG), Section IV, Conservation Practice Standard, Water Well (642)
- NRCS National Engineering Manual (NEM)
- NRCS National Environmental Compliance Handbook
- NRCS Cultural Resources Handbook
- NRCS General Manual

---

**STATE CONTACT**

---

Allen Gehring, State Conservation Engineer  
515-284-4357  
[allen.gehring@ia.usda.gov](mailto:allen.gehring@ia.usda.gov)