

# NATURAL RESOURCES CONSERVATION SERVICE

## CONSERVATION PRACTICE STANDARD

### AGRICULTURAL SECONDARY CONTAINMENT FACILITY

(No.)  
CODE 710

#### DEFINITION

Permanently located above ground facilities designed to provide secondary containment of on-farm oil products

#### PURPOSE

To minimize the risk of accidental release of stored oil products used in agricultural operations to support one or more of the following purposes:

- Control excessive release of organics into groundwater and surface waters.
- Control excessive suspended sediment and turbidity into surface water.

#### CONDITIONS WHERE PRACTICE APPLIES

This practice is applicable to agricultural areas where:

- Oil product storage facilities are used or will be used for agricultural purposes.
- Spillage of liquid would pose a threat to soil contamination; and excessive organics into groundwater and surface water.
- Soils and topography are suitable for construction.
- This practice applies for sites that have fuel tank capacities greater than 1,100 gallons or more than 3,300 gallons oil tank storage capacity.

On-farm oil products, such as diesel fuel, gasoline, lube oil, hydraulic oil, adjuvant oil, crop oil, vegetable oil, or animal fat, as identified by U.S. EPA's Oil Spill, Prevention, Control, and Countermeasure (SPCC) regulation (40 CFR 112 Oil Pollution Prevention).

This practice does not apply to the removal of existing tanks.

For facilities with less than 3,300 gallons oil tank storage capacity refer to NRCS conservation practice standard Fuel Facilities, Above Ground Storage (713).

#### CRITERIA

##### General Criteria Applicable To All Purposes

**Laws, Rules and Regulations.** Design, construction, and siting shall comply with all Federal, state, local and tribal laws, and regulations.

The owner or operator shall be responsible for securing all required permits or approvals and for performing in accordance with such laws and regulations.

Farms with more than 1,320 gallons of oil products stored in above ground containers 55 gallons and larger shall have an SPCC Plan meeting the requirements of the Code of Federal regulations, Title 40, Part 112, Oil Pollution Prevention, prepared and implemented. All facilities required to have an SPCC plan shall have secondary containment for all oil product storage containers 55 gallons and larger.

Michigan regulations for aboveground storage tanks including aboveground storage tank systems under the Storage and Handling of Flammable and Combustible Liquids (FL/CL) Rules, promulgated under the authority of the Michigan Fire Prevention Code, 1941 PA 207, as amended, being R 29.4101 et seq., of the Michigan Administrative Code. Rules R 29.4103 through R 29.4106 of Part 1 of the FL/CL Rules adopt by reference four specific editions of the National Fire Protection Association (NFPA) standards.

Farms with storage capacity of more than 10,000 gallons, or that have had an oil spill shall have a Spill Prevention, Control, and Counter-measure (SPPC) Plan certified by a licensed Professional Engineer as required by EPA.

Prevent outside runoff water from entering the facility.

Tanks shall be located on reinforced concrete pads or in a dike walled secondary containment where leaks can be detected. The concrete pad or dike walled containment shall extend a minimum distance of two feet beyond the outside dimensions of all tanks in the facility. The minimum distance between storage tanks shall be three feet. The reinforced concrete pad shall extend through the

vehicle filling area or a separated concrete pad for fueling shall be constructed. Tanks shall be stably mounted on solid timbers, solid cement blocks, manufactured cradles or equivalent to protect the tank bottom from corrosion due to contact with the ground. The tanks shall be elevated to allow for a visible inspection of all tank surfaces.

**Containment.** Containment systems shall be manufactured or fabricated for the purpose of containing oil, fuel, or other regulated liquid.

Anchor non-mobile tanks to the bottom of the secondary containment facility to prevent the tank from floating in the event of a catastrophic leak or accidental spill.

Storage tanks shall be of single compartment design and constructed of steel in accordance with Underwriters Laboratories standards; UL142, UL2080, and UL2085 type tanks.

Secondary containment shall be double walled tanks or an impermeable barrier such as a lined dike wall and floor.

The dike wall and floor may be reinforced concrete, steel, modular block walls or an earthen dike that is lined in accordance with Pond Sealing or Lining, Flexible Membrane, 521A. Dike walled secondary containments shall:

- Contain 110% of the capacity of the largest storage tank
- Have 6 inch depth for freeboard
- Where the facility is not roofed, have additional storage volume for 6 inches of rainwater accumulation in order to contain the 25 year/24 hour rainfall event.

Containment structures shall have provisions for accumulated rainwater removal. Types of water removal systems can be a sump and pump or a valve and sealed outlet pipe. All accumulated rainwater will be tested for contamination before removal from the containment structure. Testing may consist of verifications that no oil sheen is present on the water surface in the dike wall secondary containment.

An area adjacent to the concrete slab for spills to accumulate and be recovered is required. This can be an area where soil or other absorbent material is placed over a concrete slab and upon contamination, material is removed-and replaced.

**Location.** Tanks shall be located away from buildings in accordance with the following table:

Tank Type	Distance from Buildings
Tanks in Vaults	0 feet
UL 2085 Protected Tank ≤ 6,000 gallons	5 feet
UL 2085 Protected Tank 6,001 – 12,000 gallons	15 feet
UL 2080 Fire Resistant Tank 0 – 12,000 gallons	25 feet
UL 142 Above Ground Tank 0 – 12,000 gallons	50 feet

Section R 29.5218 of the Michigan Administrative Code has a significant list of restrictions on placement of facilities. The following requirements apply in addition to, or replace those requirements.

The distance between fueling facility sites shall be at least 100 feet.

Site facilities or provide surface drainage to prevent the runoff from a 25-year, 24-hour storm from inundating the fueling facility.

The facility floor shall be a minimum of two feet above the seasonal high water table. All field tile (subsurface drains) within 50 feet of a fueling facility shall be removed and capped.

Facilities with secondary containment shall be replaced with the following isolation distances between fueling facilities and drinking water wells:

Well Type	Isolation Distance
Private <sup>1/</sup>	50 feet
Public - Type IIB and III <sup>2/</sup>	75 feet
Public - IIA <sup>2/</sup>	200 feet

<sup>1/</sup> As defined by Part 127, 1978 PA 368, Michigan Public Health Code.

<sup>2/</sup> As defined by 1976 PA 399, Michigan Safe Drinking Water Act.

- Type II wells are classified as any non-community public water supply. This may be further broken down into Type IIA which is a water supply with 25 or more employees and water use of 20,000 gallons per day or more.

- Type IIB water supply services 25 or more employees and uses less than 20,000 gallons per day.
- Type III public wells include Grade A dairy operations or farms with less than 25 non-family member employees.

**Additional well requirements.** Wells must be properly constructed and unused wells properly abandoned, as determined by MDEQ, local health department, or a registered well drilling contractor.

The NRCS State Conservation Engineer or a non-NRCS professional engineer licensed in the State of Michigan may approve variances to the NRCS standard for isolation distances for Types IIB and III water wells with concurrence from the Michigan Department of Environmental Quality. The local health department shall be provided a copy of the decision wherever a variance is used to reduce the well isolation distance less than identified in the table above from an existing well.

Deviations from isolation distances authorized through issuance of well construction permits may incorporate additional criteria in accordance with the Michigan Safe Drinking Water Act (1976, PA 399) or Part 127, Water Supply and Sewer Systems of the Michigan Public Health Code (1978 PA 368).

**Structural Design.** Structural design of the concrete pads shall be as follows:

- 1) Foundation shall be a minimum of 4 inches of compacted, well-graded sand or gravel over a native mineral soil or rock or a consistent depth of compacted sub-base. The foundation sand or gravel shall have no more than 7% of material pass the #200 sieve and be free of clay lumps.
- 2) The minimum concrete pad thickness shall be 6 inches. Where vehicles greater than 40,000 pounds gross weight are expected drive across the pad, a minimum thickness of 8 inches is required.
- 3) The minimum steel ratio shall be 0.18% in each direction. The maximum steel spacing shall be 18 inches.
- 4) The reinforcing steel shall be placed a 1½ inches clear from the top surface of the concrete.

- 5) Concrete shall meet the requirements of Michigan Construction Specifications MI-158, Reinforced Concrete.

Design and construction of reinforced concrete dike wall containments 4 feet deep or less shall be as follows:

- 1) Foundation shall be a minimum of 4 inches of compacted, well-graded sand or gravel over a native mineral soil or rock or a consistent depth of compacted sub-base. The foundation sand or gravel shall have no more than 7% of material pass the #200 sieve and be free of clay lumps.
- 2) Concrete mix and placement shall meet the requirements of Michigan Construction Specification MI-158, Reinforced Concrete.
- 3) Concrete floor and walls shall be 8 to 10 inches in thickness.
- 4) Reinforcing steel shall be #5 bars with a maximum 12-inch spacing located approximately in the middle of the walls and floor.

Design of concrete dike wall containments shall be by the most recent edition of American Concrete Institute Code 350, Environmental Structures.

Steel dike wall containments shall be of a commercial manufacturer for the purpose of fuel containment. Steel dike wall containments shall be installed to meet manufacturer's recommendations.

Roofs shall meet the wind and snow load requirements of the current Michigan Building Code. Roof structures shall not contain any combustible material. Roofs shall be at least 6 feet above the fuel tank.

**Safety.** Storage tanks shall be protected from accidental contact by vehicles, tractors, and other farm equipment.

Provide adequate ventilation in roofed structures to prevent the buildup of excess fumes and development of vacuum or pressure exceeding the design pressure as a result of filling, emptying, or atmospheric temperature changes.

Storage facilities shall be properly marked with signs. A No Smoking sign shall be placed near the fueling area. Fill ports shall be painted with the proper paint code; Gasoline-Red, Diesel-Yellow, and Kerosene-Brown.

Provide security measures to limit unauthorized access to the storage tanks and secondary containment structure(s).

### CONSIDERATIONS

Evaluate the potential risk to water quality associated with agricultural oil, fuel, and/or liquid storage planned or present on the farm.

Consider using the Tier I Qualified Facility SPCC Plan Template to develop and SPCC Plan where the farm has not had a discharge into waters of the US for the past three years and individual storage tanks are less than or equal to 5,000 gallons. A link to the template is:

<http://www.epa.gov/emergencies/content/spcc/tier1temp.htm>

Another SPCC template offered by the National Milk Federation of Producers is:

<http://www.nmpf.org/files/file/SPCC-Plan-Template-Final-Sept-20-2010-FORM.pdf>

Consider using double wall tanks instead of a dike wall containment to reduce cost associated with disposal of contaminated water from within the containment.

Consider the potential effects of installation and operation of fueling facilities on the cultural, archeological, historical, and economic resources.

It is recommended that all piping and controls be located above ground and within the secondary containment.

Automatic shutoff valves on electronically operated dispensers should be considered.

### PLANS AND SPECIFICATIONS

Plans and specifications shall be prepared in accordance with the criteria of this standard and shall describe the requirements for applying the practice to achieve its intended purpose(s).

Support data documentation requirements are as follows:

- Inventory and evaluation records
  - Assistance notes or special report

- Survey notes, where applicable
  - Design survey
  - Construction layout survey
  - Construction check survey
- Design records
  - Physical data, functional requirements and site constraints, where applicable
  - Soils/subsurface investigation report, where applicable
- Design and quantity calculations
- Construction drawings/specifications with:
  - Location map
  - Designed by” and “Checked by” names or initials
  - Approval signature
  - Job class designation
  - Initials from preconstruction conference
  - As-built notes
- Construction inspection records
  - Assistance notes or separate inspection records
  - Construction approval signature
- Record of any variances and well isolation distance deviations approved, where applicable
- Record of approvals of in-field changes affecting function and/or job class, where applicable.

### OPERATION AND MAINTENANCE

An Operation and Maintenance (O&M) plan shall be developed for this practice. The O&M plan shall be consistent with the purposes of the practice, its intended life, safety requirements, and the criteria for the design.

### REFERENCES

Underwriters Laboratories, Standard No. 142, “Standard for Steel Aboveground Tanks for Flammable and Combustible Liquids”

Environmental Protection Agency, The Spill Prevention, Control, and Countermeasure (SPCC) rule -

<http://www.epa.gov/emergencies/content/spcc/index.htm>