

Underground Outlet (Feet) 620

DEFINITION

A conduit installed beneath the surface of the ground to collect surface water and convey it to a suitable outlet.

PURPOSE

Dispose of excess water from water and sediment control basins, diversions, subsurface drains, surface drains, trickle tubes or principal spillways from dams (outside the dam area only), or other concentrations without causing damage by erosion or flooding.

CONDITIONS WHERE PRACTICE APPLIES

This practice applies where: (1) excess surface water needs to be disposed of; (2) a buried outlet is needed for diversions (362), water and sediment control basins (638), or similar practices; (3) an underground outlet can be installed that will safely dispose of excess water; and (4) surface outlets are impractical because of stability problems, climatic conditions, land use, or equipment traffic.

CRITERIA

Underground outlets shall be planned, designed, and installed to meet all federal, state, local and tribal laws and regulations.

Capacity. The underground outlet shall be designed, alone or in combination with other practices, with adequate capacity to ensure that the water and sediment control basin, diversion, or other practices function according to the standard for the specific practice. For example, an underground outlet can be used in combination with a grassed waterway or a surface drain to carry part of the design flow. The capacity of the underground outlet for natural or

constructed basins shall be adequate for the intended purpose without causing excessive damage to crops, vegetation, or improvements.

Inlet. An inlet can be a collection box, a perforated riser, or other appropriate device. Its capacity shall be adequate to provide the maximum design flow in the conduit. Flow-control devices shall be installed as necessary. Perforated risers must be of durable material, structurally sound, and resistant to damage by rodents or other animals. If burning of vegetation is likely to create a fire hazard, the inlet shall be fire resistant. Blind inlets can be used where they are effective. Collection boxes must be large enough to facilitate maintenance and cleaning operations. The inlet must have an appropriate trash guard to ensure that trash or other debris entering the inlet passes through the conduit without plugging. The flow capacity of the trash guard shall be greater than the inlet capacity to ensure that the trash guard does not restrict the flow. It must also have an animal guard to prevent the entry of rodents or other animals.

Pressure-relief wells shall be designed and installed as needed to control pressure. If junction boxes and other structures are needed, they shall be designed and installed in a manner that facilitates cleaning and other maintenance activities.

Hydraulics. Underground outlets shall be continuous conduits, tubing, or tile. Joints shall be hydraulically smooth, and the manufacturer shall recommend the materials and methods used. If a pressure system is used, joints shall be adequate to withstand the design pressure, including surges and vacuum. The maximum velocity must not exceed the safe velocity for the conduit materials and installation.

Lines shall be adequate to carry the design flow when the outlet and all inlets are operating at design capacity. Positive grade shall be maintained in all sections of an underground outlet. Capacity shall be based on the pipe size or on other flow control devices to prevent water from the upper inlets from discharging through the lower inlets. The minimum conduit diameter shall be 3 inches.

Materials. Materials shall meet or exceed the design requirements against leakage and shall withstand internal pressure or vacuum and external loading. Plastic, concrete, aluminum, and steel shall meet the

requirements specified in the applicable ASTM standard. All materials specified for NRCS conservation practice Subsurface Drains (606) can be used for underground outlets. Conduits, however, can be perforated or nonperforated, depending on the design requirements. A filter fabric wrap (sock) or equivalent shall be used if migration of soil particles around conduit is anticipated. All exposed plastic materials shall be protected from degradation due to exposure to sunlight.

Outlet. The outlet shall be sufficiently stable for all anticipated flow conditions. It shall be designed for the maximum anticipated water surface at design flow. A continuous section of closed conduit or a headwall can be used at the outlet. If a closed conduit is used, it shall be durable and strong enough to withstand all anticipated loads, including those caused by ice. Outlets shall not be placed in areas of active erosion. If fire is a hazard, the outlet shall be fire resistant. All outlets must have animal guards to prevent the entry of rodents or other animals. Animal guards must be hinged to allow passage of debris.

Protection. All disturbed areas shall be reshaped and regraded so that they blend with the surrounding land features and conditions. Visual resources must be given the same consideration as other design features. Areas that are not to be farmed or covered by structural works shall be established to vegetation or otherwise protected from erosion as soon as practicable after construction. Use vegetation adapted to the site that will accomplish the desired purpose. Preference shall be given to native species in order to reduce the introduction of invasive plant species; provide management of existing invasive species; and minimize the economic, ecological, and human health impacts that invasive species may cause. If native plant materials are not adaptable or proven effective for the planned use, then non-native species may be used. Refer to the Field Office Technical Guide, Section II, Invasive Plant Species, for plant materials identified as invasive species.

CONSIDERATIONS

Consider the potential effects of installation and operation of underground outlets on the cultural, archaeological, historic and economic resources.

Evaluate potential for tree roots to infiltrate into the pipe. Consider avoiding use of perforated pipe within 100 feet of water-loving trees such as willow and cottonwood or within 50 feet of other tree species.

Consider effects on the water budget, especially on volumes and rates of runoff, infiltration, evaporation, transpiration, deep percolation, and ground water recharge.

Consider effects on the volume of downstream flow that might cause undesirable environmental, social, or economic effects.

Evaluate potential use for water management.

Consider effects on erosion and the movement of sediment, pathogens, and soluble and sediment-attached substances that would be carried by runoff.

Consider effects on the visual quality of downstream water resources.

Consider the construction-related effects on the quality of downstream watercourses.

Consider effects on wetlands or water-related wildlife habitats.

Evaluate potential impact on water quality due to agri-chemicals in outflow.

Consider depth of underground outlet in regard to tillage equipment depth and maintenance, if applicable.

PLANS AND SPECIFICATIONS

Plans and specifications shall be prepared in accordance with the criteria of this standard and shall describe the requirements for applying the practice to achieve its intended use.

Support data documentation requirements are as follows:

- Inventory and evaluation records
 - CONS-6 notes or special report
- Survey notes, where applicable
 - Design survey

- Construction layout survey
- Construction check survey
- Design records
 - Physical data, functional requirements and site constraints, where applicable
 - Soils/subsurface investigation report, where applicable
- Design and quantity calculations
- Construction drawings/specifications with:
 - Location map
 - “Designed by” and “Checked by” names or initials
 - Approval signature
 - Job class designation
 - Initials from preconstruction conference
 - As-built notes
- Construction inspection records
 - Assistance notes or separate inspection records
 - Construction approval signature
- Record of any variances approved, where applicable
- Record of approvals of in-field changes affecting function and/or job class, where applicable

OPERATION AND MAINTENANCE

An Operation and Maintenance (O&M) plan shall be developed for this practice. The O&M plan shall be consistent with the purposes of the practice, its intended life, safety requirements, and the criteria for the design.