

## Engineering Interpretations

### ***Building Site Development***

Soil properties influence development of building sites, including the selection of the site, the design of the structure, construction, post construction performance, and maintenance. Soil limitation ratings of slight, moderate, and severe are given for shallow excavations, dwellings with and without basements, small commercial buildings, local roads and streets, and lawns, landscaping, and golf fairways.

#### ***Shallow Excavations***

Shallow excavations are trenches or holes dug in the soil to a maximum depth of 5 or 6 feet. They are used for pipelines, sewer lines, telephone and power transmission lines, basements, open ditches, and cemeteries. The ratings are based on the soil properties that influence ease of digging and resistance to sloughing.

#### ***Dwellings With or Without Basements***

These are single-family houses of three stories or less. The foundation is assumed to be spread footings of reinforced concrete built on undisturbed soil at a depth of 2 feet or the depth of maximum frost penetration, whichever is deeper, for houses without basements, or at a depth of 7 feet if a basement is constructed. The ratings are based on properties affecting soil strength and settlement under a load, and those that affect excavation and construction costs.

#### ***Small Commercial Buildings***

Limitation ratings are given for the undisturbed soil on which small commercial buildings of less than three stories without basements are built. The foundation is assumed to be placed on spread footings of reinforced concrete at a depth of 2 feet or the depth of maximum frost penetration, whichever is deeper.

#### ***Local Roads and Streets***

Limitation ratings are given for the use of soils for construction of improved local roads and streets that have all-weather surfacing, commonly of asphalt, gravel with binder in it, or concrete, and that are expected to carry automobile traffic all year. These roads and streets are graded to shed water, and conventional drainage measures are provided. With the probable exception of the hard surface, roads and streets are built mainly from the soil at hand.

#### ***Lawns, Landscaping, and Golf Fairways***

The soils are rated for their use in establishing and maintaining turf for lawns and golf fairways and ornamental trees and shrubs for residential type landscaping. The ratings are based on the use of soil material at the location with some land smoothing. Irrigation may or may not be needed and is not a criterion in rating. Traps, trees, roughs, and greens are not considered as part of the golf fairway. The properties considered are those listed that affect plant growth and trafficability after vegetation is established.

*This subsection includes:*

- **(a) Building Site Development**

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
AmC2: Armster-----	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Not limited	
	~wetness (slightly limited)	0.22	~wetness (limited)	0.90	~slope (limited)	0.83				
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15						
ArC3: Armster-----	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	~too clayey (moderately limited)	0.60
	~wetness (slightly limited)	0.22	~wetness (limited)	0.90	~slope (limited)	0.83				
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15						
Au: Auxvasse-----	Very limited ~shrink-swell (very limited)	1.00	Very limited ~wetness (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Limited ~wetness (limited)	0.60
	~wetness (limited)	0.99	~shrink-swell (limited)	0.88	~wetness (limited)	0.60	~wetness (limited)	0.60		
Bk: Blake-----	Very limited ~shrink-swell (very limited)	1.00	Limited ~wetness (limited)	0.95	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	~too clayey (moderately limited)	0.60
	~wetness (slightly limited)	0.29	~shrink-swell (moderately limited)	0.47						
Bm: Blake-----	Slightly limited ~wetness (slightly limited)	0.29	Limited ~wetness (limited)	0.95	Not limited		Not limited		~too clayey (moderately limited)	0.60
			~shrink-swell (slightly limited)	0.09						
Haynie-----	Not limited		Not limited		Not limited		Not limited		Not limited	

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
Bm: (cont)										
Waldron-----	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.59	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.28	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.28	Very limited ~too clayey (very limited) ~wetness (slightly limited)	1.00  0.28
Bo:										
Booker-----	Very limited ~wetness (very limited) ~shrink-swell (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~wetness (very limited) ~shrink-swell (very limited)	1.00  1.00	Very limited ~wetness (very limited) ~too clayey (very limited)	1.00  1.00
CaB:										
Calwoods-----	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.79	Very limited ~wetness (very limited) ~shrink-swell (limited)	1.00  0.91	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.45	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.45	Moderately limited ~wetness (moderately limited) ~too acid (slightly limited)	0.45  0.12
CbB2:										
Calwoods-----	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.79	Very limited ~wetness (very limited) ~shrink-swell (limited)	1.00  0.91	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.45	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.45	Moderately limited ~wetness (moderately limited) ~too clayey (moderately limited) ~too acid (slightly limited)	0.45  0.30  0.12
Cd:										
Cedargap-----	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Moderately limited ~flooding (moderately limited) ~droughty (slightly limited)	0.60  0.00

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
Ce: Cedargap-----	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Limited ~small stones (limited) ~flooding (moderately limited) ~large stones (slightly limited)	0.75 0.60 0.25
Cf: Cedargap variant-----	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~too clayey (moderately limited)	0.60
Ch: Chariton-----	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00 0.99	Very limited ~wetness (very limited) ~shrink-swell (limited)	1.00 0.81	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00 0.60	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00 0.60	Limited ~wetness (limited)	0.60
CnF: Chilhowie-----	Very limited ~slope (very limited) ~depth to bedrock (moderately limited) ~shrink-swell (moderately limited)	1.00 0.45 0.45	Very limited ~hard bedrock <40" (very limited) ~slope (very limited) ~shrink-swell (moderately limited)	1.00 1.00 0.32	Very limited ~slope (very limited) ~depth to bedrock (moderately limited) ~shrink-swell (moderately limited)	1.00 0.45 0.45	Very limited ~slope (very limited) ~depth to bedrock (moderately limited) ~shrink-swell (moderately limited)	1.00 0.45 0.45	Very limited ~slope (very limited) ~too clayey (moderately limited) ~depth to bedrock (slightly limited)	1.00 0.60 0.30
Gasconade-----	Not Rated Not Rated ~hard bedrock <20" (very limited) ~slope (very limited)	1.00 1.00	Very limited ~hard bedrock <40" (very limited) ~slope (very limited) ~large stones (moderately limited)	1.00 1.00 0.33	Very limited ~hard bedrock <20" (very limited) ~slope (very limited) ~large stones (moderately limited)	1.00 1.00 0.33	Very limited ~hard bedrock <20" (very limited) ~slope (very limited) ~large stones (moderately limited)	1.00 1.00 0.33	Very limited ~shallow to bedrock (very limited) ~droughty (very limited) ~slope (very limited)	1.00 1.00 1.00

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
CnF: (cont) Crider-----	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00
Co: Coland-----	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Moderately limited ~flooding (moderately limited)	0.60
	~shrink-swell (very limited)	1.00	~shrink-swell (very limited)	1.00	~shrink-swell (very limited)	1.00	~shrink-swell (very limited)	1.00	~too clayey (moderately limited)	0.60
	~wetness (moderately limited)	0.59	~wetness (very limited)	1.00	~wetness (slightly limited)	0.28	~wetness (slightly limited)	0.28	~wetness (slightly limited)	0.28
CrC: Crider-----	Slightly limited ~slope (slightly limited)	0.15	Slightly limited ~slope (slightly limited)	0.15	Limited ~slope (limited)	0.83	Not limited		Not limited	
CrD2: Crider-----	Limited ~slope (limited)	0.76	Limited ~slope (limited)	0.76	Very limited ~slope (very limited)	1.00	Limited ~slope (limited)	0.63	Limited ~slope (limited)	0.63
Do: Dockery-----	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Very limited ~flooding (very limited)	1.00	Moderately limited ~flooding (moderately limited)	0.60
	~wetness (moderately limited)	0.59	~wetness (very limited)	1.00	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~wetness (slightly limited)	0.28
	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~wetness (slightly limited)	0.28	~wetness (slightly limited)	0.28		
Fc: Mine and stockpiles----	Not rated		Not rated		Not rated		Not rated		Not rated	

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value						
GaC: Gasconade-----	Very limited ~hard bedrock <20" (very limited)	1.00	Very limited ~hard bedrock <40" (very limited)	1.00	Very limited ~hard bedrock <20" (very limited)	1.00	Very limited ~hard bedrock <20" (very limited)	1.00	Very limited ~shallow to bedrock (very limited)	1.00
	~shrink-swell (moderately limited)	0.45	~slope (slightly limited)	0.15	~slope (limited)	0.83	~shrink-swell (moderately limited)	0.45	~droughty (very limited)	1.00
	~slope (slightly limited)	0.15	~large stones (slightly limited)	0.02	~shrink-swell (moderately limited)	0.45	~large stones (slightly limited)	0.02	~too clayey (moderately limited)	0.60
GdF: Gasconade-----	Not Rated		Very limited		Very limited		Very limited		Very limited	
	Not Rated		~hard bedrock <40" (very limited)	1.00	~hard bedrock <20" (very limited)	1.00	~hard bedrock <20" (very limited)	1.00	~shallow to bedrock (very limited)	1.00
	~hard bedrock <20" (very limited)	1.00	~slope (very limited)	1.00	~slope (very limited)	1.00	~slope (very limited)	1.00	~droughty (very limited)	1.00
	~slope (very limited)	1.00	~large stones (moderately limited)	0.33	~large stones (moderately limited)	0.33	~large stones (moderately limited)	0.33	~slope (very limited)	1.00
Rock outcrop---	Not rated		Not rated		Not rated		Not rated		Not rated	
GoD: Goss-----	Moderately limited		Moderately limited		Very limited		Moderately limited		Limited	
	~slope (moderately limited)	0.60	~slope (moderately limited)	0.60	~slope (very limited)	1.00	~shrink-swell (moderately limited)	0.45	~large stones (limited)	0.91
	~shrink-swell (moderately limited)	0.45	~large stones (moderately limited)	0.33	~shrink-swell (moderately limited)	0.45	~large stones (moderately limited)	0.33	~small stones (limited)	0.62
	~large stones (moderately limited)	0.33	~shrink-swell (slightly limited)	0.29	~large stones (moderately limited)	0.33	~slope (slightly limited)	0.16	~droughty (moderately limited)	0.53

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value						
GoF: Goss-----	Very limited		Very limited		Very limited		Very limited		Very limited	
	~slope (very limited)	1.00	~slope (very limited)	1.00						
		1.00		1.00		1.00		1.00		1.00
	~shrink-swell (moderately limited)	0.45	~large stones (moderately limited)	0.31	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~droughty (slightly limited)	0.01
	~shrink-swell (moderately limited)	0.45	~shrink-swell (slightly limited)	0.29	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~large stones (limited)	0.91
	~large stones (moderately limited)	0.31	~shrink-swell (slightly limited)	0.22	~large stones (slightly limited)	0.17	~large stones (moderately limited)	0.31	~small stones (limited)	0.62
	~large stones (slightly limited)	0.17	~large stones (slightly limited)	0.17	~large stones (moderately limited)	0.31	~large stones (slightly limited)	0.17		
HcB: Hatton-----	Moderately limited		Very limited		Limited		Moderately limited		Slightly limited	
	~shrink-swell (moderately limited)	0.45	~wetness (very limited)	1.00	~slope (limited)	0.68	~shrink-swell (moderately limited)	0.45	~too acid (slightly limited)	0.30
	~wetness (moderately limited)	0.45	~shrink-swell (slightly limited)	0.22	~shrink-swell (moderately limited)	0.45				
He: Haynie-----	Not limited		Not limited		Not limited		Not limited		Not limited	
Hg: Hodge-----	Very limited		Very limited		Very limited		Very limited		Very limited	
	~flooding (very limited)	1.00	~flooding (very limited)	1.00						
									~droughty (slightly limited)	0.20
HoC2: Holstein-----	Moderately limited		Slightly limited		Limited		Moderately limited		Slightly limited	
	~shrink-swell (moderately limited)	0.45	~shrink-swell (slightly limited)	0.17	~slope (limited)	0.83	~shrink-swell (moderately limited)	0.45	~large stones (slightly limited)	0.01
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15	~shrink-swell (moderately limited)	0.45				

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
HoD2: Holstein-----	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.76  0.45	Limited ~slope (limited) ~shrink-swell (slightly limited)	0.76  0.17	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.63  0.45	Limited ~slope (limited)	0.63
HrE: Holstein-----	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (slightly limited)	1.00  0.17	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited)	1.00
Rock outcrop---	Not rated		Not rated		Not rated		Not rated		Not rated	
KeC2: Keswick-----	Very limited ~shrink-swell (very limited) ~wetness (moderately limited) ~slope (slightly limited)	1.00  0.59  0.15	Very limited ~wetness (very limited) ~shrink-swell (limited) ~slope (slightly limited)	1.00  0.93  0.15	Very limited ~shrink-swell (very limited) ~slope (limited) ~wetness (slightly limited)	1.00  0.83  0.28	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.28	Slightly limited ~wetness (slightly limited) ~too acid (slightly limited)	0.28  0.12
KeD: Keswick-----	Very limited ~shrink-swell (very limited) ~slope (limited) ~wetness (moderately limited)	1.00  0.76  0.59	Very limited ~wetness (very limited) ~shrink-swell (limited) ~slope (limited)	1.00  0.90  0.76	Very limited ~slope (very limited) ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  1.00  0.28	Very limited ~shrink-swell (very limited) ~slope (limited) ~wetness (slightly limited)	1.00  0.63  0.28	Limited ~slope (limited) ~wetness (slightly limited) ~too acid (slightly limited)	0.63  0.28  0.12

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
KsC3: Kswick-----	Very limited ~shrink-swell (very limited)	1.00	Very limited ~wetness (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Moderately limited ~too clayey (moderately limited)	0.60
	~wetness (moderately limited)	0.59	~shrink-swell (very limited)	1.00	~slope (limited)	0.83	~wetness (slightly limited)	0.28	~wetness (slightly limited)	0.28
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15	~wetness (slightly limited)	0.28			~too acid (slightly limited)	0.12
Le: Orthents-----	Not Rated		Not Rated		Not Rated		Not Rated		Not Rated	
	Not Rated		Not Rated						Not Rated Not Rated	
LnE: Lindley-----	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00	Very limited ~slope (very limited)	1.00
	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45		
Ma: Marion-----	Very limited ~shrink-swell (very limited)	1.00	Very limited ~wetness (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Very limited ~shrink-swell (very limited)	1.00	Limited ~wetness (limited)	0.60
	~wetness (limited)	0.99	~shrink-swell (limited)	0.87	~wetness (limited)	0.60	~wetness (limited)	0.60	~too acid (slightly limited)	0.12
MeC2: Menfro-----	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~shrink-swell (moderately limited)	0.41	Limited ~slope (limited)	0.83	Moderately limited ~shrink-swell (moderately limited)	0.45	Not limited	
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15	~shrink-swell (moderately limited)	0.45				

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
MeD2: Menfro-----	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.76  0.45	Limited ~slope (limited) ~shrink-swell (slightly limited)	0.76  0.17	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.63  0.45	Limited ~slope (limited)	0.63
MeE: Menfro-----	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (slightly limited)	1.00  0.17	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited)	1.00
MeF: Menfro-----	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (slightly limited)	1.00  0.17	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited)	1.00
MoB: Mexico-----	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.99	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.60	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.60	Limited ~wetness (limited)	0.60
MpB2: Mexico-----	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.99	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.60	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.60	Limited ~wetness (limited) ~too clayey (moderately limited)	0.60  0.60

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
Ms: Modale-----	Moderately limited ~wetness (moderately limited)	0.59	Very limited ~wetness (very limited)	1.00	Moderately limited ~shrink-swell (moderately limited)	0.45	Moderately limited ~shrink-swell (moderately limited)	0.45	Slightly limited ~wetness (slightly limited)	0.28
	~shrink-swell (moderately limited)	0.45	~shrink-swell (very limited)	1.00	~wetness (slightly limited)	0.28	~wetness (slightly limited)	0.28		
Mu: Moniteau-----	Very limited		Very limited		Very limited		Very limited		Limited	
	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~wetness (limited)	0.60
	~wetness (limited)	0.99	~wetness (very limited)	1.00	~wetness (limited)	0.60	~wetness (limited)	0.60	~flooding (moderately limited)	0.60
	~shrink-swell (moderately limited)	0.45	~shrink-swell (slightly limited)	0.27	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45		
Nd: Nodaway-----	Very limited		Very limited		Very limited		Very limited		Very limited	
	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~flooding (very limited)	1.00	~flooding (very limited)	1.00
	~shrink-swell (moderately limited)	0.45	~wetness (limited)	0.61	~shrink-swell (moderately limited)	0.45	~shrink-swell (moderately limited)	0.45		
	~wetness (slightly limited)	0.01	~shrink-swell (moderately limited)	0.45						
Pt: Putnam-----	Very limited		Very limited		Very limited		Very limited		Limited	
	~shrink-swell (very limited)	1.00	~wetness (very limited)	1.00	~shrink-swell (very limited)	1.00	~shrink-swell (very limited)	1.00	~wetness (limited)	0.99
	~wetness (very limited)	1.00	~shrink-swell (limited)	0.98	~wetness (limited)	0.99	~wetness (limited)	0.99		
Qu: Rock quarry----	Not rated		Not rated		Not rated		Not rated		Not rated	

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value						
Rv: Riverwash-----	Not rated		Not rated		Not rated		Not rated		Not rated	
SaC2: Sampsel-----	Very limited ~shrink-swell (very limited)	1.00	Moderately limited ~too clayey (moderately limited)	0.60						
	~wetness (moderately limited)	0.51	~wetness (very limited)	1.00	~slope (limited)	0.83	~wetness (slightly limited)	0.13	~wetness (slightly limited)	0.13
	~slope (slightly limited)	0.15	~slope (slightly limited)	0.15	~wetness (slightly limited)	0.13				
Sh: Sharon-----	Very limited ~flooding (very limited)	1.00	Moderately limited ~flooding (moderately limited)	0.60						
			~wetness (moderately limited)	0.35					~too acid (slightly limited)	0.12
SnD: Snead-----	Not Rated Not Rated		Limited ~wetness (limited)	0.95	Very limited ~slope (very limited)	1.00	Limited ~slope (limited)	0.63	Limited ~slope (limited)	0.63
	~slope (limited)	0.76	~slope (limited)	0.76					~too clayey (moderately limited)	0.60
	~wetness (slightly limited)	0.29	~shrink-swell (slightly limited)	0.06					~large stones (slightly limited)	0.01
Tm: Twomile-----	Limited ~wetness (limited)	0.99	Very limited ~wetness (very limited)	1.00	Limited ~wetness (limited)	0.60	Limited ~wetness (limited)	0.60	Limited ~wetness (limited)	0.60
			~shrink-swell (slightly limited)	0.05					~too acid (slightly limited)	0.12
W: Water-----	Not rated		Not rated		Not rated		Not rated		Not rated	

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
Wa: Waldron-----	Very limited ~shrink-swell (very limited) ~wetness (moderately limited)	1.00  0.59	Very limited ~shrink-swell (very limited) ~wetness (very limited)	1.00  1.00	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.28	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.28	Very limited ~too clayey (very limited) ~wetness (slightly limited)	1.00  0.28
WeB: Weller-----	Very limited ~shrink-swell (very limited) ~wetness (slightly limited)	1.00  0.29	Very limited ~shrink-swell (very limited) ~wetness (limited)	1.00  0.95	Very limited ~shrink-swell (very limited) ~slope (slightly limited)	1.00  0.15	Very limited ~shrink-swell (very limited)	1.00	Not limited	
WeC2: Weller-----	Very limited ~shrink-swell (very limited) ~wetness (slightly limited) ~slope (slightly limited)	1.00  0.29  0.15	Very limited ~shrink-swell (very limited) ~wetness (limited) ~slope (slightly limited)	1.00  0.95  0.15	Very limited ~shrink-swell (very limited) ~slope (limited)	1.00  0.83	Very limited ~shrink-swell (very limited)	1.00	Not limited	
WnB: Winfield-----	Moderately limited ~shrink-swell (moderately limited) ~wetness (slightly limited)	0.45  0.22	Limited ~wetness (limited) ~shrink-swell (moderately limited)	0.90  0.45	Moderately limited ~shrink-swell (moderately limited) ~slope (slightly limited)	0.45  0.15	Moderately limited ~shrink-swell (moderately limited)	0.45	Not limited	
WnC2: Winfield-----	Moderately limited ~shrink-swell (moderately limited) ~wetness (slightly limited) ~slope (slightly limited)	0.45  0.22  0.15	Limited ~wetness (limited) ~shrink-swell (moderately limited) ~slope (slightly limited)	0.90  0.45  0.15	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.83  0.45	Moderately limited ~shrink-swell (moderately limited)	0.45	Not limited	

Montgomery and Warren Counties, Missouri: Detailed Soil Map Legend

Building Site Development

(The information in this table indicates the dominant soil condition but does not eliminate the need for onsite investigation. The numbers in the value columns range from 0.00 to 1.00. The larger the value, the greater the potential limitation. See text for further explanation of ratings in this table.)

Map symbol and soil name	Dwellings without basements		Dwellings with basements		Small commercial buildings		Local roads and streets		Lawns and landscaping	
	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value	Rating class and limiting features	Value
WnD2: Winfield-----	Limited ~slope (limited) ~shrink-swell (moderately limited) ~wetness (slightly limited)	0.76  0.45  0.22	Limited ~wetness (limited) ~slope (limited) ~shrink-swell (moderately limited)	0.90  0.76  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Limited ~slope (limited) ~shrink-swell (moderately limited)	0.63  0.45	Limited ~slope (limited)	0.63
WnE: Winfield-----	Very limited ~slope (very limited) ~shrink-swell (moderately limited) ~wetness (slightly limited)	1.00  0.45  0.22	Very limited ~slope (very limited) ~wetness (limited) ~shrink-swell (moderately limited)	1.00  0.90  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited)	1.00
WnF: Winfield-----	Very limited ~slope (very limited) ~shrink-swell (moderately limited) ~wetness (slightly limited)	1.00  0.45  0.22	Very limited ~slope (very limited) ~wetness (limited) ~shrink-swell (moderately limited)	1.00  0.90  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited) ~shrink-swell (moderately limited)	1.00  0.45	Very limited ~slope (very limited)	1.00