

## **Irrigation Water Conveyance Low-Pressure, Underground, Plastic Pipeline (ft) Code 430EE**

### **DEFINITION**

A pipeline and appurtenances installed in an irrigation system.

### **SCOPE**

This standard applies to underground thermoplastic pipelines from 4 to 18 in. in diameter that are subject to internal pressures up to 50 lb/in.<sup>2</sup>.

The standard includes the design criteria for these irrigation pipelines, the minimum installation requirements, and the specifications for the thermoplastic pipe to be used. It applies to pipelines with stands and vents open to the atmosphere and to pipelines not open to the atmosphere but provided with pressure-relief valves and air-and-vacuum valves.

### **PURPOSE**

To prevent erosion or loss of water quality or damage to the land, to make possible the proper management of irrigation water, and to reduce water conveyance losses.

### **CONDITIONS WHERE PRACTICE APPLIES**

All pipelines shall be planned and located to serve an integral part of an irrigation water distribution or conveyance system designed to facilitate the conservation use and management of the soil and water resources on a farm or group of farms.

The water supply and quality and rate of irrigation delivery for the area served by the pipeline shall be sufficient to make irrigation practical for the crops to be grown and the irrigation water application methods to be used.

Plastic pipelines installed according to this standard shall be placed only in suitable soils where the bedding and backfill requirements can be fully met.

### **DESIGN CRITERIA**

Irrigation water conveyance, low pressure, underground, plastic pipelines shall be planned, designed, and installed to meet all federal, state, local and tribal laws and regulations.

**Working pressure.** The pipeline shall be designed to meet all service requirements without a static or working pressure including hydraulic transients, at any point greater than the maximum allowable working pressure of the pipe used at that point. The static or working pressure of pipelines open to the atmosphere shall include freeboard.

Maximum allowable working pressure for low-head plastic irrigation pipe shall be 50 ft or head or 22 lb/in.<sup>2</sup>.

Pipelines constructed of 50-lb/in.<sup>2</sup> plastic irrigation pipe or the IPS pipe covered by this standard shall have a working pressure no greater than 50 lb/in.<sup>2</sup>.

Plastic pipeline requiring a working pressure greater than 50 lb/in.<sup>2</sup> shall be constructed according to the requirements specified in 430-DD of this standard.

Plastic pipe pressure rating normally is based on a water temperature of 73.4 degrees F. Factors for adjusting allowable working pressure for higher water temperature given in table 1.

Table 1. — Pressure rating factors for PVC and PE pipe for water at elevated temperatures

Temperature	PVC	PE
deg F		
73.4	1.00	1.00
80	.88	.92
90	.75	.81
100	.62	.70
110	.50	—
120	.40	—
130	.30	—
140	.22	—

Note: To obtain the pipe’s reduced pressure rating because of a water temperature greater than 73.4 deg F, multiply the normal pressure rating by the appropriate factor from table.

**Friction losses.** For design purposes, friction head losses shall be no less than those computed by the Hazen-Williams equation, using a roughness coefficient, c, equal to 150.

**Flow velocity.** The full-pipe design water velocity in the pipeline when operating at system capacity should not exceed 5 ft/s.

**Capacity.** The design capacity of the pipeline shall be based on whichever of the following criteria requires the larger amount of water.

1. The capacity shall be sufficient to deliver the volume of water required to meet the peak-period consumptive use of the crop or crops to be irrigated.
2. The capacity shall be sufficient to provide an adequate irrigation stream for all methods of irrigation planned.

**Outlets.** Appurtenances to deliver water from the pipe system to the land, to a ditch or a reservoir, or to any surface pipe system shall be known as outlets. Outlets shall have adequate capacity at design working pressure to deliver the required flow to (1)

the hydraulic gradeline of a pipe or ditch, (2) a point at least 6 in. above the field surface, or (3) the design in surface elevation in a reservoir.

**Check valves.** A check valve shall be installed between the pump discharge and the pipeline if backflow may occur.

Stands open to the atmosphere. Stands shall be used wherever water enters the pipeline system to avoid entrapment of air, to prevent surge pressures, to avoid collapse because of negative pressures, and to prevent the pressure from exceeding the maximum allowable working pressure of the pipe. Open stands may be required at other locations in low-head systems to perform other functions. Stands shall be constructed of steel pipe or other approved material and be supported on a base adequate to support the stand and prevent movement or undue stress on the pipeline. Open stands shall be designed to meet or exceed the following criteria:

1. Each stand shall allow at least 1 ft of freeboard above design working head. The stand height above the centerline of the pipeline shall be such that neither the static head nor the design working head plus freeboard exceeds the allowable working pressure of the pipe.
2. The top of each stand shall extend at least 4 ft above the ground surface except for surface gravity inlets or where visibility is not a factor. Gravity inlets shall be equipped with a trash guard.
3. The downward water velocity in stands shall not exceed 2 ft/s. The inside diameter of the stand shall not be less than the inside diameter of the pipeline. This downward velocity criterion applies only to stands having vertical offset inlets and outlets.
4. If the water velocity in the inlet (from the pump or other water source) equals or exceeds three times the velocity in the outlet pipeline, the centerline of the inlet shall have a minimum vertical offset from the centerline of the outlet at least equal to the sum of the diameters of the inlet and outlet pipes.

TECHNICAL GUIDE  
SECTION IV  
State-Wide  
Irrigation Water Conveyance Low Pressure  
Underground Plastic Pipeline 430EE-3

5. The cross-sectional area of stands may be reduced above a point 1 ft above the top of the upper inlet or outlet pipe, but the reduced cross section shall not be such that it would produce an average velocity of more than 10 ft/s if the entire flow were discharging through it.
6. Vibration-control measures, such as special couplers or flexible pipe, shall be provided as needed to insure that vibration from pump discharge pipes is not transmitted to stands.

Sand traps, when combined with a stand, shall have a minimum inside dimension of 30 in. and shall be constructed so that the bottom is at least 24 in. below the invert of the outlet of the pipeline. The downward velocity of flow of the water in a sand trap shall not exceed 0.25 ft/s.

Gate stands shall be of sufficient dimension to accommodate the gate or gates and shall be large enough to make the gates accessible for repair.

Float valve stands shall be large enough to provide accessibility for maintenance and to dampen surge.

Stands closed to the atmosphere. If pressure-relief valves and air-vacuum valves are used instead of open stands, all requirements under "Stands Open to the Atmosphere" shall apply except as modified below.

The inside diameter of the closed stand shall be equal to or greater than that of the pipeline for at least 1-ft. above the top of the uppermost inlet or outlet pipe. To facilitate attaching the pressure-relief valve and the air-and-vacuum valve, the stand may be capped at this point or, if additional height is required, the stand may be extended to the desired elevation by using the same inside diameter or a reduced cross section. If a reduced section is used, the cross-sectional area shall be such that it would produce an average velocity of no more than 10 ft/s if the entire flow were discharge through it. If no vertical offset is required between the pump discharge pipe and the outlet pipeline and the discharge pipe is "doglegged" below ground, the stand shall extend to a least 1 ft. above the highest part of the pump discharge pipe.

An acceptable alternative design for stands requiring no vertical inlet (when inlet velocity is less than three times that of the outletting pipeline) shall be:

1. Construct the dogleg section of the pump discharge pipe with the same nominal diameters as that of the pipeline.
2. Install the pressure-relief valve and the air-and vacuum valve on top the upper horizontal section of the dogleg.

Pressure relief and air-and vacuum valves shall be installed on stands with nominal size pipe required to fit the valves' threaded inlets.

**Vents.** Vents must be designed into systems open to the atmosphere to provide for the removal and entry of air and protection from surge. They shall:

1. Have a minimum freeboard of 1 ft above the hydraulic gradeline. The maximum height of the vent above the centerline of the pipeline must not exceed the maximum allowable working pressure of the pipe.
2. Have a cross-sectional area at least one half the cross-sectional area of the pipeline (both inside measurements) for a distance of at least one pipeline diameter up from the centerline of the pipeline. Above this elevation the vent may be reduced to 2 in. in diameter.

These cross-sectional requirements shall apply when an air-and-vacuum valve is used instead of a vent, but the reduced section shall be increased to the nominal size pipe required to fit the valve's threaded inlet. An acceptable alternative is to install this valve in the side of a service outlet, provided that the riser is properly located and adequately sized. If both an air-and-vacuum valve and a pressure-relief valve are required at the location, the 10-ft/s velocity criterion given under "Stands Open to the Atmosphere" shall apply to the reduced section.

3. Be located at the downstream end of each lateral, at summits in the line, and at points where there are changes in grade in a downward direction of flow of more than 10 degrees.

**Air-and-vacuum valves.** An air-and-vacuum valve, which has a large venting orifice, exhausts large quantities of air from the pipeline during filling operations and allows air to reenter the line and prevents a vacuum from forming during emptying operations. This type of valve is sometimes called air-vacuum valve or air vent and vacuum-relief valve. It is not continuous acting because it does not allow further escape of air at working pressure once the valve closes.

Air-and-vacuum valves installed according to the standards for “Vents” can be used instead of open vents at any or all the locations listed in (3) under “Vents.”

Air-and-vacuum valves installed according to the standards for “Stands Closed to the Atmosphere” can be used in conjunction with pressure-relief valves as an alternative to open pump stands. A pipeline is considered open to the atmosphere if at least one stand, vent, or service outlet is unclosed and located so that it cannot be isolated from the system by line gates or valves.

The diameter of the orifice (opening that controls air flow during filling and emptying operations) of an air-and-vacuum valve shall equal or exceed that specified below for the appropriate diameter of pipeline.

Diameter of orifice	Diameter of pipeline
(in)	(in)
¾	4
1¼	6
1¾	8
2¼	10
2¾	12
3¼	14
3½	15
3¾	16
4	18

Manufacturers of air-and-vacuum valves marketed for use under this standard shall provide dimensional  
USDA-NRCS-MICH  
Underground, Plastic (FT) (430EE).doc  
Issue 12/91 Review 5/02

data, which shall be the basis for selecting and accepting these valves.

**Pressure-relief valves.** Pressure-relief valves can be used on low-pressure plastic pipelines as an alternative to stands open to the atmosphere. A pressure-relief valve shall serve the pressure-relief function of the open stand or vent for which it is an alternative.

Pressure-relief valves do not function as air-release valves and shall not be used as substitutes for such valves if release of entrapped air is required. Pressure-relief valves shall be used in conjunction with air-and-vacuum valves at all pump stands and at the end of pipelines if needed to relieve surge at the end of the lines.

The flow capacity of pressure-release valves shall be the pipeline design flow rate with a pipeline pressure no greater than 50 percent more than the permissible working pressure for the pipe.

The pressure at which the valve starts to open shall be marked on each pressure-relief valve. Adjustable pressure-relief valves shall be sealed or otherwise altered to insure that the adjustment marked on the valve is not changed.

Manufacturers of pressure-relief valves marketed for use under this standard shall provide capacity tables, based on performance tests, that give the discharge capacity of the valves at the maximum permissible pressure and differential pressure settings. Such tables shall be the basis for design of pressure setting and of acceptance of these valves.

**Drainage.** Provisions shall be made for completely draining the pipeline if a hazard is imposed by freezing temperatures, drainage is recommended by the manufacture of the pipe or drainage of the line is specified for the job. If provisions for drainage are required, drainage outlets shall be located at all low places in the line. These outlets can drain into dry wells or to points of lower elevation. If drainage cannot be thus provided by gravity, provisions shall be made for emptying the line by pumping or by other means.

**Flushing.** If provisions are needed for flushing the line free of sediment or other foreign material, a  
Irrigation Water Conveyance Pipeline-Low-Pressure,

suitable valve shall be installed at the distal end of the pipeline.

**Thrust control.** Anchors or thrust blocks shall be provided on pipelines having a working pressure of 25 lb/in.2 or greater at abrupt changes in pipeline grade, changes in horizontal alignment, or reduction in pipe size to absorb any axial thrust of the pipeline. Thrust blocks may also be needed at the end of the pipeline and at inline control valves.

The pipe manufacturer’s recommendations for thrust control shall be followed. In absence of such recommendations, the following formula should be used to design thrust blocks:

$$A = ((98 HD^2)/B)\sin(a/2)$$

Where:

- A = Area of thrust block required
- H = Maximum working pressure in ft
- D = Inside diameter of pipe in ft
- B = Allowable passive pressure of the soil in lb/ft<sup>2</sup>
- a = Deflection angle of pipe bend

Area of thrust blocks for dead ends and tees shall be 0.7 times the area of block required for a 90°-deflection angle of pipe bend.

If adequate soil tests are not available, the allowable bearing soil pressure can be estimated from table 2.

Table 2. —Allowable soil bearing pressure

Natural soil material	Depth of cover to center of thrust block			
	2 ft	3 ft	4 ft	5 ft
	-----lb/ft <sup>2</sup> -----			
Sound bedrock	8,000	10,000	10,000	10,000
		0		0
Dense sand and gravel mixture (assumed Ø = 40°)	1,200	1,800	2,400	3,000
Dense fine to coarse sand (assumed Ø = 35°)	800	1,200	1,650	2,100

Silt and clay mixture (assumed Ø = 25°)      500      700      950      1,200

Soft clay and organic soils (assumed Ø = 10°)      200      300      400      500

**Materials.** All materials described and required in this standard shall meet or exceed the minimum requirements listed for materials under “Specifications.”

**CONSIDERATIONS**

Consider the potential effects of installation and operation of irrigation water conveyance, low pressure, underground, plastic pipelines on the cultural, archeological, historic and economic resources.

**PLANS AND SPECIFICATIONS**

Plans and specifications shall be prepared in accordance with the criteria of this standard and shall describe the requirements for applying the practice to achieve its intended use.

Support data documentation requirements are as follows:

- Inventory and evaluation records
  - Assistance notes or special report
- Survey notes, where applicable
  - Design survey
  - Construction layout survey
  - Construction check survey
- Design records
  - Physical data, functional requirements and site constraints, where applicable
  - Soils/subsurface investigation report, where applicable
- Design and quantity calculations
- Construction drawings/specifications with:
  - Location map
  - “Designed by” and “Checked by” names or initials
  - Approval signature
  - Job class designation
  - Initials from preconstruction conference

- As-built notes
- Construction inspection records
  - Assistance notes or separate inspection records
  - Construction approval signature
- Record of any variances approved, where applicable
- Record of approvals of in-field changes affecting function and/or job class, where applicable.

## PLANNING CONSIDERATIONS

### *Water Quantity*

1. Effects on the water budget, especially on infiltration and evaporation.
2. Effects on downstream flows or aquifers that would affect other water uses or users.
3. Potential use for irrigation water management.
4. Effects of installing a pipeline on vegetation that may have been located next to the original conveyance.

### *Water Quality*

1. Effects of installing the pipeline (replacing other types of conveyances) on channel erosion or the movement of sediment and soluble and sediment-attached substances carried by water.
2. Effects on the movement of dissolved substances into the soil, percolation below the root zone or to ground water recharge.
3. Effects of controlled water delivery on the temperatures of water resources that could cause undesirable effects on aquatic and wildlife communities.
4. Effects on wetlands or water-related wildlife habitats.
5. Effects on the visual quality of water resources.