

Georgia NRCS Well Standard Checklist:
(circle (Y)es or (N)o)

I. Clear of overhead and underground utilities <u>before</u> construction	Y	N	
II. State and Local permits	Y	N	NA
Georgia Water Well Standards Act: Irrigation wells having casing of internal diameter of more than four inches or capable of producing 100,000 gallons of water per day or more shall be constructed only after the division has issued a letter of concurrence or a permit to the landowner and must be metered.			
III. Buffers:			
Georgia Water Well Standards Act:			
(A) Ten (10) feet or more from a sewer line ;	Y	N	
(B) Fifty (50) feet or more from a septic tank ;	Y	N	
(C) One hundred (100) feet or more from a septic tank absorption field ;	Y	N	
(D) One hundred fifty (150) feet or more from a cesspool or seepage pit ;	Y	N	
(E) One hundred (100) feet or more from an animal or fowl enclosure .	Y	N	
NRCS Practice Standards:			
Required:			
(A) Animal Mortality Facility ; One hundred (100) feet or more from an	Y	N	
(B) Pest Management – Located distances required by product labels	Y	N	
(C) Waste Field Storage Area ; One hundred fifty (150) feet or more up gradient and 300 feet or more down gradient	Y	N	
Recommended:			
(A) Nutrient Management . Not less than 150 feet up gradient and not less than 300 feet down gradient of and application area.	Y	N	
(B) Waste Storage Facility. Wet: Not less than 200 feet (non-potable); 300 feet (potable private); 500 feet (potable, public). Dry: Not less than 100 feet (non-potable); 200 feet (potable, private); 300 feet (potable, public)	Y	N	
(C) Waste Storage Lagoon . Not less than 100 feet (non-potable); 300 feet (potable)	Y	N	
IV. Grout	Y	N	
Georgia Water Well Standards Act:			
Individual wells (animal watering) - The minimum depth of the grout seal shall be at least 10 feet below ground surface.			
Irrigation wells - The minimum depth of the grout seal shall be at least 20 feet below ground surface.			
V. Curbing	Y	N	
Georgia Water Well Standards Act: All wells shall be curbed at the surface by the owner with a watertight curbing of concrete at least four inches thick and extending at least two feet in all directions from the well casing and sloping away from the casing.			
VI. Casing extends at least 1 foot above curbing.	Y	N	

VII. Are livestock excluded from access to the well	Y	N
VIII. Location of well show on scaled map.	Y	N
IV. Does electrical wiring conform to the National Electric Code	Y	N

Signature

Date