



- Notes:
1. All fasteners used shall be hot dip galvanized.
 2. Self-sealing roofing nails shall be used to attach galvanized metal roofing.
 3. Lumber and Posts shall be pressure treated in conformance with ASTM D 1760.
 4. Siding (gables) used shall be exterior grade.
 5. All nails shall be galvanized zinc ring shank or spiral shank.
 6. Refer to NDS Chapters 10, 11, 12, and 13 to determine design requirements for fasteners.
 7. Use hurricane clips and 4D nails to fasten purlins to trusses.
 8. The roof shall have a minimum 30° overhang on all sides measured from the edge of the concrete pad.
 9. Trusses may be either pre-fabricated wood or steel. Trusses shall be engineered to meet local building codes and the design sealed by a Florida Registered Professional Engineer. The truss shall be designed for a minimum ___ psf live load plus dead load. Contractor shall provide NDRCS details for all truss connections and bracing prior to installation.
 10. Refer to local building codes for hurricane clip and strap requirements.

Agrichemical Handling Facility
Pole Shelter Details

Standard DWG. No. FL-309A.dwg
Date 5/7/2013
Sheet 1 of 2

| Date | Revisions | Title |
|------|-----------|-------|
| | Approved | |

| Date | |
|------|----------|
| | Designed |
| | Drawn |
| | Checked |
| | Approved |

United States Department of Agriculture
Natural Resources Conservation Service

File No. FL-309A.dwg
Drawing No. 5/7/2013
Sheet 1 of 2

Agrichemical Handling Facility
Pole Shelter Details