

IRRIGATION REGULATING RESERVOIR*(New Welded Steel Tank Used in Conjunction with Dust Control Sprinkler Systems)***Oklahoma Conservation Practice Job Sheet 552****USDA Natural Resources Conservation Service (NRCS)****May, 2006**

Name of Feedyard _____

**SCOPE**

The work shall consist of designing, furnishing and installing a new welded steel tank for water storage including the foundation, tank, coating system and engineering certification. It does not include any distribution pipelines, valves, electrical or tank level controls.

PUBLIC AND PRIVATE UTILITIES

Utilities are defined to be overhead and underground power or communication lines, and pipelines. The contractor should conduct their own search and discovery for utilities in order to lessen or avoid potential damages. The CALL OKIE one call system is to be used. The owner/operator shall complete OK-ENG-45, UTILITIES INVENTORY prior to any ground disturbance and return it to a USDA-NRCS representative.

AWWA STANDARDS

The welded steel tank for water storage shall meet American Water Works Association (AWWA) D100-96. This shall include but is not limited to: materials, general design, sizing, accessories, welding, shop fabrication, erection, inspection/testing and foundation design.

The coating systems for coating the inside and outside surfaces of the steel tank shall meet American Water Works Association (AWWA) Standard D102-97. This standard is for steel tanks used for potable water storage in water supply service.

ENGINEERING CERTIFICATION

An engineering certification, wet stamped by an engineer licensed in the state of Oklahoma, shall be furnished to USDA-NRCS. The certification shall state that the steel tank, foundation, and installation meet AWWA D100-96 and that the coating system installed on the inside and outside surfaces of the steel tank meet AWWA D102-97.

The engineering certification shall also provide the tank capacity (net volume) in U.S. gallons. Capacity of the tank is defined by AWWA D100-96, as the net volume that may be removed from the tank filled to the top capacity level (TCL) and emptied to bottom capacity level (BCL). In a ground-supported tank, the BCL shall be the water level in the tank when the tank is emptied through the specified discharge fitting.

MEASUREMENT

The tank capacity (net volume) rounded to the nearest whole U.S. gallon, will be based on the

engineering certification as required in Engineering Certification.

An onsite check of the completed steel tank and installation will be performed by a USDA-NRCS engineer licensed in the state of Oklahoma.

**TANK ACCESSORIES
(Section 7 AWWA Standard D100-96)**

Two (2) shell manholes shall be provided in the first ring of the tank at locations designated by the purchaser.

The size and point of attachment of the pipe connections shall be specified by the purchaser. Pipe connections shall be protected from freezing by insulation or other methods.

The tank shall be equipped with an overflow device placed down the side of the tank to convey any tank overflow to the ground as specified by the tank designer. The overflow device point of discharge at ground level shall be designated by the purchaser.

The tank shall be equipped with an outside tank ladder as specified in section 7.4 of AWWA D100-96.

The tank shall be equipped with roof openings as specified in section 7.6 of AWWA D100-96.

The tank shall be equipped with tank vents as specified in section 7.7 of AWWA D100-96.

**GUARANTEE
(SECTION 1.3 AWWA Standard D100-96)**

The Constructor shall guarantee the structure against any defective materials or workmanship, including paint and painting for a period of one year from the date of completion. If any materials or workmanship prove to be defective within one year, they shall be replaced or repaired by the constructor.

OTHER CONSTRUCTION DETAILS:

I acknowledge receipt of the construction job sheet JS 552 along with any attached construction details explaining the requirements for proper completion of my storage tank. The requirement for completion of an OK-ENG-45, UTILITIES INVENTORY has been reviewed with me and I agree to install my storage tank according to the construction specifications contained in the job sheet.

Feed yard Owner/Operator/Mgr

Date

The United States Department of Agriculture (USDA) prohibits discrimination in its programs on the basis of race, color, national origin, sex, religion, age, disability, political beliefs and marital or familial status. (Not all prohibited bases apply to all programs.) Persons with disabilities who require alternative means for communication of program information (Braille, large print, audiotape, etc.) should contact USDA's TARGET Center at 202-720-2600 (voice and TDD).

To file a complaint, write the Secretary of Agriculture, U.S. Department of Agriculture, Washington, D.C. 20250 or call 1-800-245-6340 (voice) or (202)720-1127 (TDD). USDA is an equal employment opportunity employer.