

**INSTRUCTIONS FOR USE OF CONSTRUCTION SPECIFICATION**  
**GROUNDWATER TESTING, CODE 355**

1. Applicability

This specification is applicable for groundwater testing to determine the quality of a groundwater supply with respect to its intended use.

2. Items to be included in the "ITEMS OF WORK AND CONSTRUCTION DETAILS" or on the plans.

- a. Location and depth of water supply.
- b. Document aquifer characteristics, geology, and history of site relative to sources of potential contamination, such as surface water, septic systems, chemical storage facilities, landfills, roads, animal waste storage or treatment facilities, or naturally occurring sources of contamination.
- c. Parameters to be tested.
- d. Frequency of testing.
- e. Document the construction method used to install the well or spring development.
- f. Description of the collection process, storing, transporting, and testing samples.
- g. Process for reporting and dissemination of test results.