


**ANIMAL MORTALITY FACILITY  
GEORGIA STANDARD DRAWINGS, STAND ALONE STRUCTURE  
20' WIDE, DEEP COMPOSTING BIN  
6" X 6" POST CONSTRUCTION**

- THE FOLLOWING DRAWINGS WERE PREPARED IN ACCORDANCE WITH PRACTICE CODES 316-ANIMAL MORTALITY FACILITY, 561 - HEAVY USE AREA, 367 - ROOFS AND COVERS AND GEORGIA BUILDING CODE (INTERNATIONAL BUILDING CODE 2006)
- DESIGN DATA REQUIRED BY IBC 2006:
  - ROOF LIVE LOAD - 20 PSF.
  - BASIC WIND SPEED OF 90 MPH AND GROUND SNOW LOAD OF 10 PSF OR BASIC WIND SPEED OF 100 MPH AND NO SNOW LOAD.
  - IMPORTANCE FACTOR, I=0.87
  - WIND EXPOSURE CATEGORY C.
  - INTERNAL PRESSURE COEFFICIENT = 0.55
- THIS DESIGN IS NOT INTENDED FOR USE IN EXTREME SOUTH AND EAST COUNTIES OF THE STATE THAT ARE SUBJECT TO HURRICANE WIND LOADS (SEE MAP BELOW)
- THIS DESIGN IS NOT INTENDED FOR CONSTRUCTION ON AN ISOLATED HILL, RIDGE, OR ESCARPMENT IN ANY REGION OF THE STATE.
- ANY CHANGES TO THESE DRAWINGS MUST BE APPROVED BY AN ENGINEER WITH JOB APPROVAL LEVEL IV OR GREATER.
- NO ADDITIONS SHOULD BE MADE TO STRUCTURE WITHOUT APPROVAL FROM NRCS.
- THESE DRAWINGS MUST BE SITE SPECIFIC TO ACCOUNT FOR WASTE PRODUCTION VALUES; LENGTH MUST BE DETERMINED.



**SITE LOCATION MAP**

THIS DESIGN IS NOT INTENDED FOR USE IN COUNTIES SUBJECT TO HURRICANE WIND LOADS SHADED GRAY ABOVE.

**UNITED STATES DEPARTMENT OF AGRICULTURE  
NATURAL RESOURCES CONSERVATION SERVICE  
HELPING PEOPLE HELP THE LAND**

**ANIMAL MORTALITY FACILITY  
COUNTY, GEORGIA**

PRE-CONSTRUCTION CERTIFICATION:

THE \_\_\_\_\_ ANIMAL MORTALITY FACILITY HAS BEEN CONSTRUCTED IN ACCORDANCE WITH THE FOLLOWING DRAWINGS AND PRACTICE CODES 316, 367, AND 561. ALL CHANGES HAVE BEEN APPROVED BY AN ENGINEER WITH JOB APPROVAL AUTHORITY LEVEL IV OR GREATER. ALL ADDITIONS HAVE BEEN APPROVED BY NRCS.

OWNER	DATE	NRCS REPRESENTATIVE	DATE	ENGINEER (IF REQUIRED)	DATE
-------	------	---------------------	------	------------------------	------

AS-BUILT CERTIFICATION:

THIS PRACTICE HAS BEEN CONSTRUCTED IN ACCORDANCE TO THESE PLANS AND MEETS NRCS STANDARDS AND SPECIFICATIONS.

NRCS REPRESENTATIVE	DATE	ENGINEER (IF REQUIRED)	DATE
---------------------	------	------------------------	------

ANIMAL MORTALITY FACILITY:

JOB CLASS: \_\_\_\_\_

HEAVY USE AREA:

JOB CLASS: \_\_\_\_\_

ROOFS AND COVERS:

JOB CLASS: \_\_\_\_\_

INDEX TO DRAWINGS:

- SHEET 1 - COVER SHEET
- SHEET 2 - PLAN VIEW  
ELEVATION VIEW  
FRONT VIEW  
GENERAL NOTES
- SHEET 3 - ROOF FRAMING PLAN
- SHEET 4 - GIRDER AND RAFTER TO POST CONNECTIONS  
HURRICANE STRAP  
HURRICANE CLIP
- SHEET 5 - WOOD TREATMENT TABLE  
FIBER REINFORCED CONTRACTION JOINT  
CONCRETE POST FOOTING DETAIL  
MECHANICAL ANCHOR POST CONCRETE FOOTING DETAIL




REVISIONS		
DATE	APPROVED	TITLE
09/05	H MCFARLAND	STATE ENGINEER
01/06	H MCFARLAND	STATE ENGINEER
07/07	H MCFARLAND	STATE ENGINEER
06/11	J HOLLOWAY	STATE ENGINEER
07/13	D ROBERTS	ACTING STATE ENGINEER
06/16	D GUTHRIE	STATE ENGINEER

Approved	_____	Date	_____
Checked	_____	Designed	W. Brown 07/07
Designed (Length)	_____	Drawn	S. Rogers 07/07
		Checked	H. McFarland 07/07
		Approved	H. McFarland 07/07


**ANIMAL MORTALITY FACILITY  
Stand Alone Structure  
With Deep Composting Bins**




File No. \_\_\_\_\_  
Drawing No. \_\_\_\_\_  
Cover  
July 2013  
Sheet 1 of 5



**PLAN VIEW**



**FRONT VIEW**



**ELEVATION VIEW**

**NOTES:**

1. ALL ENTRANCE AREAS SHALL BE STABILIZED USING PRACTICE STANDARD 561 - HEAVY USE AREA.
2. ALL POSTS SHALL BE SET IN CONCRETE WITH CONCRETE OR GRAVEL FOOTING PAD (SEE CONCRETE POST FOOTING DETAIL ON SHEET 5).
3. THE BUILDING SITE SHALL BE CLEARED AND GRUBBED AS REQUIRED. PROPER DRAINAGE SHALL BE PROVIDED AROUND THE ENTIRE BUILDING SO THAT RUNOFF WATER DOES NOT ENTER OR POND NEAR BUILDING. DESIGN FOR ROOF RUNOFF IN ACCORDANCE WITH PRACTICE CODE 558 - ROOF RUNOFF MANAGEMENT OR STABILIZE SOIL AROUND BUILDING USING PRACTICE CODE 342 - CRITICAL AREA PLANTING.
4. CONCRETE FLOORS AND FOOTINGS SHALL BE PLACED ON FIRM SOIL. ALL LOOSE SOIL SHALL BE REMOVED. IF FILL MATERIAL IS USED, PLACE IN 9" THICK LAYERS AND COMPACT WITH SHEEPSFOOT ROLLER OR OTHER EQUIVALENT COMPACTION METHOD.
5. ALL LUMBER, INCLUDING THE POSTS, IN CONTACT WITH LITTER, COMPOST, OR CONCRETE SHALL BE PRESSURE TREATED (SEE WOOD TREATMENT TABLE ON SHEET 5).
6. ALL DIMENSION LUMBER SHALL BE SOUTHERN PINE NO. 2 OR BETTER.
7. ALL NAILS, BOLTS AND OTHER CONNECTORS SHALL BE OF HOT-DIPPED ZINC COATED GALVANIZED STEEL, STAINLESS STEEL, SILICON BRONZE, OR COPPER. NAILS SHALL HAVE SPIRALED OR RINGED (ANNULAR) SHANKS. ALL REFERENCES TO "GALVANIZED" IN THIS SET OF DRAWINGS REFERS TO THE ABOVE LISTED COATINGS.
8. ROOFING SHALL BE 29 GAUGE GALVANIZED METAL. SEALANT SHALL BE APPLIED TO ALL LAPS.
9. ON SITE WATER SOURCE IS NECESSARY TO MAINTAIN MOISTURE CONTENT OF COMPOST.
10. CALL BEFORE YOU DIG: 811, 1-800-282-7411 OR 770-623-4344.

Date	07/07
Designed	W. Brown
Drawn	S. Rogers H. McFarland
Checked	J. Holloway
Approved	H. McFarland

**ANIMAL MORTALITY FACILITY**  
Stand Alone Structure  
With Deep Composting Bins




File No.  
ga-eng-316-c1\_rev\_062016

Drawing No.  
Plan & Elevation

REVISIONS			
DATE	APPROVED	TITLE	
09/05	H. MCFARLAND	STATE ENGINEER	
01/06	H. MCFARLAND	STATE ENGINEER	
07/07	H. MCFARLAND	STATE ENGINEER	
07/13	D. ROBERTS	ACTING STATE ENGINEER	

01/07/2013  
Sheet 2 of 5



**ROOF FRAMING PLAN**

Date 07/07  
 Designed W. Brown  
 Drawn S. Rogers  
 Checked H. McFarland  
 Approved J. Holloway  
 Date 07/07  
 Drawn H. McFarland  
 Checked J. Holloway  
 Approved H. McFarland  
 Date 07/07  
 Drawn H. McFarland  
 Checked J. Holloway  
 Approved H. McFarland

**ANIMAL MORTALITY FACILITY**  
 Stand Alone Structure  
 With Deep Composting Bins




File No.  
ga-eng-316-c1\_rev\_062016


Drawing No.  
Roof Plan

01/07/2013  
Sheet 3 of 5

REVISIONS			
DATE	APPROVED	TITLE	
09/05	H. MCFARLAND	STATE ENGINEER	
01/06	H. MCFARLAND	STATE ENGINEER	
07/07	H. MCFARLAND	STATE ENGINEER	
07/13	D. ROBERTS	ACTING STATE ENGINEER	




**GIRDER AND RAFTER TO POST CONNECTIONS**



**HURRICANE CLIP**  
(USE AT RAFTER TO GIRDER CONNECTIONS WITHOUT POSTS)

**NOTES:**

1. MINIMUM UPLIFT RESISTANCE FOR HURRICANE STRAP IS 746 LBS.
2. STRAP SHALL BE 2" OR WIDER. CENTER STRAP ON RAFTER TO RAFTER BUTT JOINTS ON CENTER POSTS.
3. USE MANUFACTURED HURRICANE CLIP FOR RAFTER TO GIRDER CONNECTIONS (WITHOUT POSTS). MINIMUM UPLIFT RESISTANCE IS 251 LBS PER CLIP. AN EXAMPLE IS SHOWN AT LEFT. INSTALL ACCORDING TO MANUFACTURER'S SPECIFICATIONS.



**HURRICANE STRAP**  
(USE AT RAFTER TO GIRDER CONNECTIONS WITH POSTS)

Date	07/07
Designed	W. Brown
Drawn	S. Rogers
Checked	H. McFarland
Approved	J. Holloway
	H. McFarland

**ANIMAL MORTALITY FACILITY**  
Stand Alone Structure  
With Deep Composting Bins




File No.  
ga-eng-316-c1\_rev\_062016

Drawing No.  
Detail 1

REVISIONS		
DATE	APPROVED	TITLE
09/05	H. MCFARLAND	STATE ENGINEER
01/06	H. MCFARLAND	STATE ENGINEER
07/07	H. MCFARLAND	STATE ENGINEER
07/13	D. ROBERTS	ACTING STATE ENGINEER

01/07/2013  
Sheet 4 of 5




CONCRETE POST FOOTING DETAIL

MECHANICAL POST ANCHOR CONCRETE FOOTING DETAIL

NOTES:

1. EXAMPLE CONNECTOR SHOWN AT LEFT.
2. MINIMUM UPLIFT RESISTANCE REQUIRED IS 1574 LBS.
3. INSTALL ACCORDING TO MANUFACTURER'S SPECIFICATIONS.
4. CONNECTOR SHALL BE GALVANIZED.
5. REBAR OR MECHANICAL POST ANCHOR REQUIRED FOR FULL POSTS ONLY.
6. MECHANICAL POST ANCHOR MAY BE USED INSTEAD OF REBAR.



FIBER REINFORCED CONTRACTION JOINT

WOOD TREATMENT TABLE

MINIMUM RETENTION RATES IN PCF					
USE	CCA	ACQ-C/D	CBA-A	CA-B	MCA
GROUND CONTACT OR FRESH WATER	0.40	0.40	0.41	0.21	0.15
IMPORTANT STRUCTURAL MEMBERS	0.60	0.60	0.61	0.31	0.23

CCA - CHROMATED COPPER ARSENATE  
 ACQ-C/D - ALKALINE COPPER QUATERNARY  
 CBA-A & CA-B - COPPER AZOLE  
 MCA - MICRONIZED COPPER AZOLE

NOTES:

1. ALL WOODEN WALLS, HALF POSTS, AND BIN FRONT WOOD SHALL MEET THE GROUND CONTACT RATES.
2. ALL SUPPORT POSTS SHALL MEET THE IMPORTANT STRUCTURAL MEMBER RATES.

Designed	W. Brown	Date	07/07
Drawn	S. Rogers		
Checked	H. McFarland		
Approved	J. Holloway		
	H. McFarland		

**ANIMAL MORTALITY FACILITY**  
 Stand Alone Structure  
 With Deep Composting Bins



File No.  
ga-eng-316-c1\_rev\_062016

Drawing No.  
Detail 2

REVISIONS			
DATE	APPROVED	TITLE	
09/05	H. MCFARLAND	STATE ENGINEER	
01/06	H. MCFARLAND	STATE ENGINEER	
07/07	H. MCFARLAND	STATE ENGINEER	
10/10	J. HOLLOWAY	STATE ENGINEER	
07/13	D. ROBERTS	ACTING STATE ENGINEER	

01/07/2013  
 Sheet 5 of 5