

**NATURAL RESOURCES CONSERVATION SERVICE  
CONSERVATION PRACTICE STANDARD**

**ROOF RUNOFF STRUCTURE**

(No.)

**CODE 558**

**DEFINITION**

Structures that collect, control, and transport precipitation from roofs.

**PURPOSES**

This practice may be applied as a part of a resource management system to support one or more of the following purposes:

- Improve water quality runoff
- Reduce soil erosion
- Increase infiltration
- Protect structures
- Increase water quantity

**CONDITIONS WHERE PRACTICE APPLIES**

This practice applies where:

- Roof runoff structures are a component of an overall resource management system.
- Roof runoff needs to be diverted away from structures or contaminated areas.
- There is a need to collect, control, and transport runoff from roofs to a stable outlet.
- Roof runoff is collected and used for other purposes.

**Utilities and Permits.** The landowner shall be responsible for locating all buried utilities in the project area, including drainage tile and other structural measures.

The landowner shall obtain all necessary permissions from regulatory agencies, including the Illinois Department of Agriculture, US Army Corps of Engineers, US Environmental Protection Agency, Illinois Environmental Protection Agency and Illinois Department of Natural Resources – Office of Water Resources, or document that no permits are required.

**CRITERIA**

**General Criteria Applicable To All Purposes**

**Design Capacity.** At minimum, a 10-year frequency, 5-minute rainfall precipitation event shall be used to design roof runoff structures, except where excluding roof runoff from manure management systems. In that case, a 25-year frequency, 5-minute precipitation event shall be used to design roof runoff structures. When gutters are used, the capacity of the downspout(s) must equal or exceed the gutter flow rate.

**Outlets.** Runoff may empty into surface or underground outlets, or onto the ground surface. Surface and underground outlets shall be sized to ensure adequate design capacity and shall provide for clean-out as appropriate. Underground outlets shall be designed in accordance with Conservation Practice Standard 620, Underground Outlet. When roof runoff empties onto the ground surface, a stable outlet shall be provided. When runoff is conveyed through a gutter and downspout system to the ground surface, an elbow and energy dissipation device shall be placed at the end of the downspout to provide a stable outlet and direct water away from the building.

Surface or ground outlets such as rock pads, rock filled trenches with subsurface drains, concrete and other erosion-resistant pads, or preformed channels may be used, particularly where snow and ice are a significant load component on roofs.

**Supports.** In regions where snow and ice will accumulate on roofs, guards and sufficient supports to withstand the anticipated design load shall be included.

**Materials.** Roof runoff structures shall be made of durable materials with a minimum design life of ten years. Roof gutters and downspouts may be made of aluminum, galvanized steel, wood, or plastic. Aluminum gutters and downspouts shall have a nominal thickness of 0.027 inches and 0.020 inches, respectively. Galvanized steel gutters and downspouts shall be at least 28 gauge. Wood shall be clear and free of knots. Wood may be redwood, cedar, or cypress. Plastics shall contain ultraviolet stabilizers. Dissimilar metals shall not be in contact with each other.

Rock-filled trenches and pads shall consist of poorly graded rock (all rock fragments approximately the same size) and be free of appreciable amounts of sand and/or soil particles. Crushed limestone shall not be used for backfill material unless it has been washed. Subsurface drains or outlets shall meet the material requirements of Conservation Practice Standard 620, Underground Outlet.

Concrete appurtenances used shall meet the requirements of NRCS National Engineering Handbook (NEH), Part 642, Specifications for Construction Contracts, Specification 32, Structure Concrete.

**Protection.** Roof runoff structures shall be protected from damage by livestock and equipment.

Where appropriate, snow and ice guards may be installed on roofs to protect gutters and reduce the hazard to humans and animals below. Gutters should be installed below the projection of the roofline to further reduce gutter damage from snow and ice.

**Additional Criteria To Increase Infiltration**

Runoff shall be routed onto pervious landscaped areas (e.g., lawns, mass planting areas, infiltration trenches, and natural areas) to increase infiltration of runoff. These areas shall be capable of infiltrating the runoff in such a way that replenishes soil moisture without adversely affecting the desired plant species.

**Additional Criteria. To Protect Structures**

Runoff shall be directed away from structure foundations to avoid wetness and hydraulic loading on the foundation.

On expansive soils or bedrock, downspout extensions shall be used to discharge runoff a minimum of five (5) feet from the structure. The discharge area for runoff must slope away from the protected structure.

**Additional Criteria To Increase Water Quantity**

Structures needed to collect and store water from roofs for potable and non-potable purposes shall be designed and installed in accordance with sound engineering principles. Storage structures for non-potable purposes such as irrigation water should be designed in accordance with Conservation Practice Standards, as appropriate.

Potable water storage structures should be constructed of materials and in a manner that will not increase the contamination of the stored water. Roof runoff collected and stored for potable uses

must be treated prior to consumption and should be tested periodically to assure that adequate quality for human consumption is maintained.

**CONSIDERATIONS**

Avoid discharging outlets near wells or into structures that discharge directly into surface waters.

**PLANS AND SPECIFICATIONS**

Plans and specifications for installing roof runoff structures shall be in keeping with this standard and shall describe the requirements for applying the practice to achieve its intended purpose. The plans and specifications shall show the location, spacing, size, and grade of all gutters and downspouts and type and quality of material to be used. Plans and specifications for other practices essential to the proper functioning of the roof runoff structure, such as underground outlet, shall be included.

## **OPERATION AND MAINTENANCE**

An Operation and Maintenance (O&M) plan shall be prepared for and reviewed with the landowner or operator. The plan shall specify that the treated areas and associated practices are inspected annually and after significant storm events to identify repair and maintenance needs. The O&M plan shall detail the level of repairs needed to maintain the effectiveness and useful life of the practice, and include:

- Keeping roof runoff structures clean and free of obstructions that reduce flow.
- Making regular inspections and performing repair maintenance as needed to ensure proper functioning of the roof runoff structures.

## **REFERENCES**

NRCS National Engineering Handbook, Part 651, Agricultural Waste Management Field Handbook, Chapter 10.

NRCS National Engineering Handbook, Part 642, Specifications for Conservation Contracts