

**NATURAL RESOURCES CONSERVATION SERVICE
CONSERVATION PRACTICE STANDARD**

WELL DECOMMISSIONING

(No.)

CODE 351

DEFINITION

The sealing and permanent closure of an inactive, abandoned, or unusable water or monitoring well.

PURPOSE

A well is decommissioned to achieve one or more of the following purposes:

- Remove a water or monitoring well from active use when it is no longer needed, it cannot be rehabilitated, or it has failed structurally.
- Remove a monitoring well from use when it is no longer capable of providing representative samples or it is providing unreliable samples.
- Eliminate a physical hazard to people, animals, and farm machinery and prevent entry of animals, debris, or other foreign substances.
- Prevent contamination of groundwater by surface water inflow.
- Restore the natural hydrogeologic conditions, to the extent possible, by preventing vertical or lateral cross-contamination or commingling of groundwaters between separate water-bearing zones.
- Eliminate the possibility of repurposing the well.
- Allow for future alternative use or management of the site.

CONDITIONS WHERE PRACTICE APPLIES

This practice applies to any water well or monitoring well selected for decommissioning.

CRITERIA

General Criteria Applicable to All Purposes

Laws and Regulations. The well decommissioning will be performed in accordance with all applicable local, State, Tribal, and Federal Law including the Illinois Water Well Construction Code, Title 77, Part 920.

Data Collection. Collect and review all as-built construction documents, maintenance records, and other available data for the well(s). Include this information in the decommissioning plan.

Well Preparation. Clear the well of all pumping equipment, valves, pipelines, grease, oil, scum, debris, and other foreign material. To the extent practicable, remove all casings, liners, and screens. Remove casing by either pulling or overdrilling (over-reaming) in accordance with guidance in ASTM D5299, "Standard Guide for Decommissioning of Groundwater Wells, Vadose Zone Monitoring Devices, Boreholes, and Other Devices for Environmental Activities."

If some or all of the casing resists removal by pulling or overdrilling, it must be cut off below the ground surface. For the cut-off depth, use the greater of two feet, the maximum potential depth for frost penetration, or the depth of any other near-surface soil fracturing process (such as desiccation).

Sealing Materials. Sealing materials must conform to the characteristics listed in ASTM D5299 and the Illinois Water Well Construction Code. Sealing materials do not require

Conservation practice standards are reviewed periodically and updated if needed. To obtain the current version of this standard, contact your Natural Resources Conservation Service [State Office](#) or visit the [Field Office Technical Guide](#).

**NRCS, Illinois
July 2015**

disinfection. Select sealing materials that have an in-place hydraulic conductivity equivalent to or less than the ground surface soil surrounding the well head.

The quality of the water used for mixing with sealing materials must meet or exceed criteria provided in ASTM D5299.

Fill (plugging) Materials. Select fill materials that are free of clay, silt, and organic and foreign matter. Select a soil gradation and a filling process that will not cause bridging during installation.

Plugging and Sealing Procedures. Do not place sealing and fill materials until after completion of the disinfection process. Before sealing the well, bring the entire column of well water to an available chlorine concentration of no less than 100 ppm, or greater concentration if specified by government authority. Agitate the well water and keep the solution undisturbed for no less than 12 hours to assure complete disinfection.

Where geologic data do not exist for a particular drilled well, the well must be sealed from the bottom up to where the well casing is removed with neat cement grout or any bentonite product manufactured for water well sealing. Otherwise, Illinois code may allow less stringent measures.

If disinfected clean pea gravel or limestone chips fill materials are allowed by the Illinois Water Well Construction Code, fill material will be placed in the bottom of the well and will extend upward to a point specified in the Illinois Water Well Construction Code.

Place sealing material in a layer no less than twenty-foot thick above the top of the fill material. Sealing materials are used to restrict vertical movement of water and to prevent comingling of waters from different production zones. Install the remainder of the seal or fill as directed in the Illinois Water Well Construction Code. If another water-bearing zone is encountered, adjust the spacing of the fill layers so that the zone is sealed. See the Illinois Water Well Construction Code for additional information on sealing wells with multiple water bearing formations. Fill the borehole to a point that is two feet from the ground surface or to the top of the cutoff casing, whichever is greater.

Use installation methods that avoid segregation, dilution, or bridging of the fill or sealing material.

For wells greater than 30 inches in diameter, place and compact backfill in a manner that minimizes segregation and bulking and prevents surface subsidence.

Casings Grouted-in-Place. Use a pressurized grouting procedure that will completely fill and seal all open spaces in the annulus. Acceptable grout sealant includes a combination of cement, or bentonite that conforms to guidance provided in ASTM D5299 and the Illinois Water Well Construction Code.

If casings are within a collapsing formation, conduct the grouting procedures concurrently with removal of the casing so that the bottom of the casing remains submerged in the grout.

Well-head Seal. Seal the interval between the ground surface and the top of the cut-off casing or last sealed layer with materials that conform to guidance in ASTM D5299. These materials may be an extension of the sealing materials used below this depth.

Mound the well-head seal above the ground surface. Grade the ground surface at the well-head in a manner that prevents ponding of surface water at the well-head.

Control of Artesian Pressure. If a well is under artesian pressure (flowing or not flowing), maintain a sufficiently high grout pressure to counteract the artesian pressure until initial grout set occurs. See Illinois Water Well Construction Code for sealing details. Use procedures for balancing pressures during grouting operations given in ASTM D5299.

CONSIDERATIONS

If allowed by State regulations, fill materials, such as sand, pea gravel, sand-gravel mix, crushed rock, or agricultural lime, can be used to fill the well provided that the zones of sealing material conform to requirements in ASTM D5299.

If feasible, consider adding a metal "target" to the top 3 inches of the well-head seal so that the decommissioned well may be easily located with a metal detector.

PLANS AND SPECIFICATIONS

Prepare plans and specifications for decommissioning a well that describe the requirements for applying the practice to achieve its intended purposes. Make a record of the

installation of this practice that includes the following:

- Location of the decommissioned well by Global Positioning System (GPS), latitude/longitude, township/range, or other georeferencing convention, of such precision that allows the ready location of the site
- Date of completion of well decommissioning
- Name of landowner
- Name, title, and address of person responsible for well decommissioning
- Total depth of well
- Length of casing prior to decommissioning
- Length of casing removed or length of casing cut off below ground level
- Lengths of casing ripped or perforated and the method used
- Inside diameter of well bore or casing
- Type or schedule of casing material (e.g., standard weight steel, or PVC Sch-80)
- Static water level measured from ground surface prior to decommissioning
- Photographs before and after decommissioning

- Types of materials used for filling and sealing, quantities used, depth intervals for installation of each type of material, and the placement method used
- Detailed documentation of all other information pertinent to site conditions and other problems encountered during decommissioning.

OPERATION AND MAINTENANCE

Inspect the practice site periodically to ensure there is no ground settlement, erosion, or other disturbance. Maintain the site in a manner that prevents ponding or surface runoff toward the site

REFERENCES

American Society for Testing and Materials, D5299, "Standard Guide for Decommissioning of Groundwater Wells, Vadose Zone Monitoring Devices, Boreholes, and Other Devices for Environmental Activities." ASTM International. 100 Barr Harbour Dr., P.O. Box C-700, West Conshohocken, PA.

Illinois Administrative Code, Title 77: Public Health, Chapter I: Department of Public Health, Subchapter r: Water and Sewage, Part 920, Illinois Water Well Construction Code. <http://www.ilga.gov/commission/jcar/admincode/077/07700920sections.html>