

**NATURAL RESOURCES CONSERVATION SERVICE
CONSERVATION PRACTICE STANDARD
ROOF RUNOFF STRUCTURE**

(No.)

CODE 558

DEFINITION

Structures that collect, control, and transport precipitation from roofs.

PURPOSES

This practice may be applied as a part of a resource management system to support one or more of the following purposes:

- Improve water quality
- Reduce soil erosion
- Increase infiltration
- Protect structures
- Increase water quantity

CONDITIONS WHERE PRACTICE APPLIES

This practice applies where:

- Roof runoff structures are a component of an overall resource management system.
- Roof runoff needs to be diverted away from structures or contaminated areas.
- There is a need to collect, control, and transport runoff from roofs to a stable outlet.
- Roof runoff is collected and used for other purposes.

CRITERIA

General Criteria Applicable to All Purposes

Laws and Regulations. Roof runoff structures shall comply with all Federal, State and local laws, rules and regulations.

Design Capacity. At minimum, a 10-year frequency, 5-minute rainfall precipitation event shall be used to design roof runoff structures, except where excluding roof runoff from manure management systems. In that case, a 25-year frequency, 5-minute precipitation event shall be used to design roof runoff structures (Refer to Agricultural Waste Management Field Handbook, NEH Part 651, Appendix 10B). When gutters are used, the capacity of the downspout(s) must equal or exceed the gutter flow rate.

Outlets. Runoff may empty into surface or underground outlets or onto the ground surface. Surface and underground outlets shall be sized to ensure adequate design capacity and shall provide for clean-out as appropriate. When runoff from roofs empties onto the ground surface, a stable outlet shall be provided. When runoff is conveyed through a gutter and downspout system, an elbow and energy dissipation device shall be placed at the end of the downspout to provide a stable outlet and direct water away from the building.

Surface or ground outlets such as rock pads, rock filled trenches with subsurface drains, concrete and other erosion-resistant pads, or preformed channels may be used, particularly where snow and ice are a significant load component on roofs.

Supports. Gutter supports (hangers) shall have sufficient strength and be spaced to withstand anticipated water, snow, and ice loads.

Mount roof gutters on fascia boards using hidden hangers, bolts and ferrules, gutter screws and ferrules, cradles, or by other approved methods. Spikes and ferrules are not acceptable.

ROOF RUNOFF STRUCTURE (558)-2

Securely fasten down spouts at the top and bottom with intermediate supports (fasteners) at maximum ten (10) foot intervals. Install fasteners in accordance with manufacturer recommendations.

Materials. Roof runoff structures shall be made of durable materials with a minimum design life of ten years. Roof gutters and downspouts may be made of aluminum, galvanized steel, wood, or plastic. Aluminum gutters and downspouts shall have a nominal thickness of 0.027 inches and 0.020 inches, respectively. Galvanized steel gutters and downspouts shall be at least 28 gauge. Wood shall be clear and free of knots. Wood may be redwood, cedar, cypress, or pressure-treated species. Plastics shall contain ultraviolet stabilizers. Dissimilar metals shall not be in contact with each other.

Rock-filled trenches and pads shall consist of poorly graded rock (all rock fragments approximately the same size) and be free of appreciable amounts of sand and/or soil particles. Crushed limestone shall not be used for backfill material unless it has been washed. Subsurface drains or outlets shall meet the material requirements of the applicable NRCS conservation practice standard.

Concrete appurtenances used shall meet the requirements of NRCS Construction Specification 32, Concrete for Minor Structures.

Protection. Roof runoff structures shall be protected from damage by livestock and equipment. Where animals or equipment may come in contact with down spouts, steel pipe, schedule 40 PVC pipe, or similar materials shall be used.

Roof gutters may be installed below the projection of the roofline to further reduce damage from snow and ice.

Additional Criteria to Increase Infiltration

Runoff shall be routed onto pervious landscaped areas (e.g., lawns, mass planting areas, infiltration trenches, and natural areas) to increase infiltration of runoff. These areas shall be capable of infiltrating the runoff in such a way that replenishes soil moisture without adversely affecting the desired plant species.

Additional Criteria to Protect Structures

Runoff shall be directed away from structure foundations to avoid wetness and hydraulic loading on the foundation.

On expansive soils or bedrock, downspout extensions shall be used to discharge runoff a minimum of five (5) feet from the structure.

The discharge area for runoff must slope away from the protected structure.

Additional Criteria to Increase Water Quantity

Structures needed to collect and store water from roofs for potable and non-potable purposes shall be designed and installed in accordance with sound engineering principles. Storage structures for non-potable purposes such as irrigation water should be designed in accordance with NRCS conservation practice standards, as appropriate.

CONSIDERATIONS

Avoid discharging outlets within 10 feet of wells or into structures that discharge directly into surface waters.

PLANS AND SPECIFICATIONS

Plans and specifications for installing roof runoff structures shall be in keeping with this standard and shall describe the requirements for applying the practice to achieve its intended purpose. The plans and specifications shall show the location, spacing, size, and grade of all gutters and downspouts and type and quality of material to be used. Plans and specifications for other practices essential to the proper functioning of the roof runoff structure, such as underground outlet, shall be included.

OPERATION AND MAINTENANCE

An operation and maintenance plan shall be developed that is consistent with the purposes of the practice, intended life, safety requirements, and the criteria for the design. The plan shall contain, but not be limited to, the following provisions:

- Keep roof runoff structures clean and free of obstructions that reduce flow.

- Make regular inspections and perform repair maintenance as needed to ensure proper functioning of the roof runoff structures.

REFERENCES

USDA, NRCS, Maryland Design Guide MD #1, "Roof Gutter Design Method".

Agricultural Waste Management Field Handbook, NEH Part 651, Appendix 10B.